

McGUIRE - UNITS 1 and 2
 9509110208 950807
 PDR ADDCK 05000369
 PDR
 3/4 3-42
 Amendment No. (Unit 1)
 (Unit 2)

TABLE 3.3-6 (Continued)

RADIATION MONITORING INSTRUMENTATION FOR PLANT OPERATIONS

| <u>MONITOR</u> | <u>CHANNELS TO TRIP/ALARM</u> | <u>MINIMUM CHANNELS OPERABLE</u> | <u>APPLICABLE MODES</u> | <u>ALARM/TRIP SETPOINT</u> | <u>ACTION</u> |
|---|-----------------------------------|--|-----------------------------|--|---------------|
| 6. Control Room Air Intake Radioactivity- High (EMF-43a and 43b) | 1 per station | 2 per station | All | $\leq 3.4 \times 10^{-4}$ $\mu\text{Ci/ml}$ | 27 |

TABLE NOTATION

- * - With fuel in the fuel storage areas or fuel building.
- ** - With irradiated fuel in the fuel storage areas or fuel building.
- *** - Must satisfy the requirements of McGuire Selected Licensee Commitment 16.11-6.

ACTION STATEMENTS

- ACTION 26 - With less than the Minimum Channels OPERABLE requirement, operation may continue provided the containment purge valves are maintained closed.
- ACTION 27 - With the number of channels less than the Minimum Channel OPERABLE requirement, immediately initiate corrective actions to restore the inoperable instrument to OPERABLE status. If the inoperable instrument has not been restored to OPERABLE status within seven calendar days, a special report shall be written detailing the cause of the inoperability, and the expected date of the return to OPERABLE status of the inoperable instrument.
- ACTION 28 - With less than the Minimum Channels OPERABLE requirement, operation may continue for up to 30 days provided an appropriate portable continuous monitor with the same Alarm Setpoint is provided in the fuel pool area. Restore the inoperable monitors to OPERABLE status within 30 days or suspend all operations involving fuel movement in the fuel building.
- ACTION 29 - Must satisfy the ACTION requirement for Specification 3.4.6.1.
- ACTION 30 - With less than the minimum channels OPERABLE requirement, operation may continue provided the Fuel Handling Ventilation Exhaust System requirements of Specification 3/4.9.11 are met.