

UNIT SHUTDOWNS AND POWER REDUCTIONS (>20%)

REPORT MONTH DECEMBER 1991 (revised)

Docket No. 50-412
 Unit Name BVPS Unit #2
 Date February 5, 1992
 Completed By David T. Jones
 Telephone (412) 393-7612

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
15	911201	S	0	H	4	N/A	ZZ	ZZZZZZ	Unit continued to operate at 46% output to load follow.
16	911206	S	0	H	5	N/A	ZZ	ZZZZZZ	Unit operated at 45% output to load follow.
17	911225	S	0	H	5	N/A	ZZ	HTEXCH	Unit reduced output from 100% to 28% for boric acid treatment of the steam generators.

¹
 F-Forced
 S-Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Exam
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Cont'd. from Previous Month
 5-Reduction
 9-Other

⁴
 Exhibit F-Instructions for
 Preparation of Data Entry Sheets
 for Licensee Event Report (LER) File
 (NUREG0161).

⁵
 Exhibit H-Same Source.