

I - MOSBA - 217A

Time

A.S. Bontwell

Date

4-8/4-9 Nite shift

19001809 → Hooked up recorder on 112 + 185 AS requested. Needs to stay hooked up for 7 days. Filled out recorder work sheet.

2HV-8220 - LLRT in progress to OFFICE OF SECRETARY MWO# 29001005. Unit II!!! DOCKETING SERVICE

A9000545 - Seismic Trigger Assembly LCO → FWC to OPS for LCO closure

H2 Recombiner Unit I surv. I/P TLW will roll LPN 24547-102

19001268 + surv 24676-101 - Need to fill + vent RVHIS sensors when RCS level is raised. Then close out surv. + MWO. Replace covers ???

If secondary performance MWO's are started need to ensure time charged to correct code per MSB.

Will need to stroke p2r spray valves 455 B+C today when maint. finishes reassembly.

18807131 - Backflushable Filter Valve 41326B will roll from Renny Bell to FWF Hot per ops. FWC back to maint. replace limit switch

Unit II D/G 2A Dewpoint or receiver/dryer K-02 out of specs. See Attached sheet for reading taken on days + nights. Scott Hammond notified George Beckhold of problem AS request by G.B. in 7:30 AM meeting 4-8-90. GB instructed RSH to contact ops and have them feed and bleed the tank for 24 hrs. P.M. does not document any corrective actions taken when out of spec. dewpoint identified, need to check on this. MWO 29000282 is written on this dryer for vibration and noise PPP

NUCLEAR REGULATORY COMMISSION
Docket No. 50-424425-CLA-3 EXHIBIT NO. II-217A
In the matter of Gen. Power Corp.
☐ Staff ☐ Applicant ☐ Intervenor ☐ Other
☐ Identified ☐ Received ☐ Rejected ☐ Witness
Date 8/25/95

9509130017 950825
PDR ADOCK 05000424
G PDR

92 PROJECT
010828

INT 217A

Time

Date 4-8/4-9 continued

Log book contains Unit I jump point readings and the test method and hook up used to take readings. This could become very important since PGL & BTM are off till Wed. and they have taken all previous data except for RSH & MSB.

~~28001826~~

19001827 - RB will roll to JWF. Turb. Emerg. Brs. oil pump problem investigated & found nothing wrong. Ops wants us to discuss with Murdock or Montgomery before signing off MWO.

19001824 - RB will roll to TWC. Safeguards test light for RCP #2 N.F.

4-8

Unit 2 Diesel Generators Air Dew Point

EG&G 911 Dew-All

DAYS			VP1114		FS3529	
{	D/G 2A	K02	43.9°F	60.9°F	39.7°F	61.4°F
		K01	60.9°F	43.9°F	61.4°F	39.7°F
{	D/G 2B	K01	33.7°F		39.5°F	
		K02	44.4°F		44.6°F	

4-8/4-9		UNIT 2A DG		NIGHTS
nights	{		K02	
		VP1114	56.7°F	
		FS 3529	60.26°F	(15.7°C)