



Nebraska Public Power District

COOPER NUCLEAR STATION
P.O. BOX 98, BROWNVILLE, NEBRASKA 68321
TELEPHONE (402)825-3811
FAX (402)825-5211

CENG958031

September 8, 1995

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555


Subject: Monthly Operating Status Report for August, Docket No. 50-298.

Gentlemen:

Enclosed for your information and use is the Cooper Nuclear Station Monthly Operating Status Report for August, 1995. The report includes Operating Status, Average Daily Unit Power Level, Unit Shutdown Data and a Narrative Summary of Operating Experience for the month of August.

Should you have any comments, or require additional information regarding this report, please contact me.

Sincerely,


J. T. Herron
Plant Manager

JTH:PLB:tib

Enclosures

cc: J. R. McPhail
R. L. Gangel
G. R. Horn
P. D. Graham
A. L. Dostal
K. C. Walden
D. D. Rieger
E. A. Lanning
A. J. Hubl
R. L. Gumm
J. H. Mueller
NRC Senior Resident Inspector
T. H. Black
R. J. Singer
T. L. Bundy
L. J. Callan
INPO Records Center
R. W. Beck and Associates
ANI Library
E. J. Mroczka
H. J. Green
F. E. Yost

150044
9509150003 950831
PDR ADOCK 05000298
R PDR

Powerful Pride in Nebraska

IE24
11

OPERATING DATA REPORT

DOCKET NO. 050-0298
UNIT CNS
DATE September 8, 1995
TELEPHONE (402) 825-5295

OPERATING STATUS

1. Unit Name: Cooper Nuclear Station Notes
2. Reporting Period: August 1995
3. Licensed Thermal Power (MWt): 2381
4. Nameplate Rating (Gross MWe): 836
5. Design Electrical Rating (Net MWe): 778
6. Maximum Dependable Capacity (Gross MWe): 787
7. Maximum Dependable Capacity (Net MWe): 764
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level To Which Restricted, If Any (Net MWe):

10. Reasons For Restriction, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours in Reporting Period	<u>744.0</u>	<u>5,831.0</u>	<u>185,568.0</u>
12. Number of Hours Reactor Was Critical	<u>744.0</u>	<u>4,715.0</u>	<u>137,905.2</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
14. Hours Generator On-Line	<u>744.0</u>	<u>4,592.5</u>	<u>135,871.8</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. Gross Thermal Energy Generated (MWH)	<u>1,745,496.0</u>	<u>10,754,288.0</u>	<u>282,065,532.0</u>
17. Gross Electric Energy Generated (MWH)	<u>565,954.0</u>	<u>3,524,854.0</u>	<u>91,643,199.0</u>
18. Net Electric Energy Generated (MWH)	<u>548,444.0</u>	<u>3,415,730.0</u>	<u>88,514,168.0</u>
19. Unit Service Factor	<u>100.0</u>	<u>78.8</u>	<u>73.2</u>
20. Unit Availability Factor	<u>100.0</u>	<u>78.8</u>	<u>73.2</u>
21. Unit Capacity Factor (Using MDC Net)	<u>96.5</u>	<u>76.7</u>	<u>62.4</u>
22. Unit Capacity Factor (Using DER Net)	<u>94.8</u>	<u>75.3</u>	<u>61.3</u>
23. Unit Forced Outage Rate	<u>0.0</u>	<u>21.2</u>	<u>8.5</u>
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>Refueling Outage: October 13, 1995; 55 days.</u>			

25. If Shut Down At End of Report Period, Estimated Date of Startup: N/A
26. Units In Test Status (Prior to Commercial Operation):

Forecast	Achieved
INITIAL CRITICALITY	<hr/>
INITIAL ELECTRICITY	<hr/>
COMMERCIAL OPERATION	<hr/>

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 050-0298

UNIT CNS

DATE September 8, 1995

TELEPHONE (402) 825-5295

MONTH August 1995

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>748</u>	17	<u>747</u>
2	<u>751</u>	18	<u>747</u>
3	<u>752</u>	19	<u>747</u>
4	<u>753</u>	20	<u>743</u>
5	<u>749</u>	21	<u>742</u>
6	<u>743</u>	22	<u>741</u>
7	<u>745</u>	23	<u>740</u>
8	<u>744</u>	24	<u>734</u>
9	<u>747</u>	25	<u>732</u>
10	<u>747</u>	26	<u>731</u>
11	<u>743</u>	27	<u>731</u>
12	<u>743</u>	28	<u>731</u>
13	<u>651</u>	29	<u>725</u>
14	<u>734</u>	30	<u>723</u>
15	<u>722</u>	31	<u>721</u>
16	<u>747</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

DOCKET NO.	050-0298
UNIT NAME	Cooper Nuclear Station
DATE	September 8, 1995
COMPLETED BY	P. L. Ballinger
TELEPHONE	(402) 825-5295

REPORT MONTH August 1995

[illegible]

1	2	3	4
F - Forced	Reason:	Method:	Exhibit G - Instructions for
S - Scheduled	A - Equipment Failure (Explain)	1 - Manual	Preparation of Data Entry
	B - Maintenance or Test	2 - Manual Scram	Sheets for Licensee Event
	C - Refueling	3 - Automatic Scram	Report (LER) File (NUREG-0161)
	D - Regulatory Restriction	4 - Continued	
	E - Operator Training & License Examination	5 - Reduced Load	Exhibit I - Same Source
	F - Administrative	6 - Other	
	G - Operational Error (Explain)		
	H - Other (Explain)		

OPERATIONS NARRATIVE COOPER NUCLEAR STATION

August 1995

Cooper Nuclear Station operated most of the month at maximum power with the plant beginning end of cycle coast down on August 20th. Rod adjustments occurred on August 6th, 13th, 15th, and 27th. Turbine testing was performed on August 13th and August 15th.

Cooper attained a unit capacity factor of 96.5 percent (MDC Net) for the month of August.