

ENCLOSURE 1

PROPOSED TECHNICAL SPECIFICATION (TS) CHANGE

SEQUOYAH NUCLEAR PLANT (SQN) UNIT 2

DOCKET NO 50-328

(TVA-SQN-TS-95-13, REVISION 1)

LIST OF AFFECTED PAGES

Unit 2

Operating License Page 11

s. Primary Coolant Outside Containment (Section 22.2. III.D.1.1)

Prior to exceeding 5 percent power Level, TVA is required to complete the leak tests on Unit 2, and results are to be submitted within 30 days from the completion of the testing.

(17) Surveillance Interval Extension

REPLACE
WITH
ATTACHED
INSERT

~~The performance interval for those surveillance requirements identified in the licensee's request for surveillance interval extension dated February 8, 1994, shall be extended to July 15, 1994, to coincide with the Cycle 6 refueling outage. The extended interval shall not exceed a total of 28 months for 18-month surveillances and 46 months for the 3-year surveillance.~~

R170

- D. Exemptions from certain requirements of Appendices G and J to 10 CFR Part 50 are described in the Office of Nuclear Reactor Regulation's Safety Evaluation Report, Supplements No. 1 and No. 5. These exemptions are authorized by law and will not endanger life or property or the common defense and security and are otherwise in the public interest. Therefore, these exemptions are hereby granted. The facility will operate, to the extent authorized herein, in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission.

A temporary exemption from General Design Criterion 57 found in Appendix A to 10 CFR part 50 is described in the Office of Nuclear Reactor Regulation's Safety Evaluation Report, Supplement No. 5, Section 6.2.4. This exemption is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest. The exemption, therefore, is hereby granted and shall remain in effect through the first refueling outage as discussed in Section 6.2.4 of Supplement 5 to the Safety Evaluation Report. The granting of the exemption is authorized with the issuance of the Facility Operating License. The facility will operate, to the extent authorized herein, in conformity with the application as amended, the provisions of the Act, and the regulations of the Commission. Additional exemptions are listed in attachment 2.

AE

E. Physical Protection

The Licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, guard training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revision to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The Safeguards Contingency Plan is incorporated into the Physical Security Plan. The plans, which contain Safeguards Information protected under 10 CFR 73.21, are entitled: "Sequoyah Physical Security Plan," with revisions submitted through November 23, 1987; and "Sequoyah Security Personnel Training and Qualification Plan," with revisions submitted through April 15, 1987. Changes made in accordance with 10 CFR 73.55 shall be implemented in accordance with the schedule set forth therein.

R65

INSERT

(17) Surveillance Interval Extension

The performance interval for the 36-month surveillance requirements in TS 4.3.2.1.3 shall be extended to May 18, 1996, to coincide with the Cycle 7 refueling outage. The extended interval shall not exceed a total of 50 months for the 36-month surveillances.