



PECO ENERGY

Robert W. Boyce
Plant Manager
Limerick Generating Station

PECO Energy Company
Limerick Generating Station
PO Box 2300
Sanatoga, PA 19464-0920
215 327 1200 Ext. 2000

September 9, 1995
Docket Nos. 50-352
50-353
License Nos. NPF-39
NPF-85

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: Licensee Event Report
Limerick Generating Station - Units 1 and 2

This voluntary LER concerns pressure setpoint drift of the Main Steam System safety relief valves (SRV) due to corrosion induced bonding within the valves. This report provides information regarding SRV setpoint test results for the previous Unit 1 operating cycle and the previous two Unit 2 operating cycles.

Reference:	Docket No. 50-352 50-353
Report Number:	2-95-009
Revision Number:	00
Discovery Date:	August 10, 1995
Report Date:	September 9, 1995
Facility:	Limerick Generating Station P.O. Box 2300, Sanatoga, PA 19464-2300

Very truly yours,

DMS:cah

cc: T. T. Martin, Administrator Region I, USNRC
N. S. Perry, USNRC Senior Resident Inspector, LGS

150017

9509150033 950909
PDR ADDCK 05000353
S PDR