

DUKE POWER COMPANY

CATAWBA NUCLEAR STATION

CLOVER, S. C. 29710

P. O. BOX 293

DOCKETED
USNRC

TELEPHONE: AREA 803
831-2482

May 7, 1980

'84 MAY 24 A11:50

To: R. M. Kollins
1576 Woodlawn

I-EP-17
5/7/84

Divine Savior Hospital
York, South Carolina 29745

DOCKET NUMBER
50-413/41402

Attention: John Bailey, Administrator

Subject: Catawba Nuclear Station
Emergency Plan - Evacuation Time Estimates
for Areas Within the Exposure Emergency Planning Zone
(10 mile radius)
File No.: CN-134.10

Special facility evacuation times are based on the number of ambulances available within York County, initial travel time to the special facility, ambulance patient capacity, average travel distance for one round trip, plus added time for driver changes, refueling, and loading and unloading of people. These times are reported for the combined patient loads of all special facilities within your emergency planning area. This would include the evacuation of those patients requiring ambulance service from Divine Savior Nursing Home as well as Divine Savior Hospital.

Within Area 9, the Special Facilities - Best Estimate - Evacuation Time is 390 minutes, and the Adverse Weather - Evacuation Time is 450 minutes.

These evacuation times have been reported to the NRC and discussed, at length, with local and state officials. Mutual agreement was reached that these values are adequate under a preliminary basis. For this reason this data should be used for information only purposes. Your cooperation in this matter is appreciated. Any questions you have may be directed to Mr. Rodney Kinard at 324-3128 ext. 2357.

J. W. Hampton, Manager
Catawba Nuclear Station

RDK/ga

cc: C. L. Thames - General Office

8406220346 840507
PDR ADOCK 05000413
G PDR

I received these copies
in the mail 5-11-80 -
for your info only.

NUCLEAR REGULATORY COMMISSION

Docket No. 50-413/414 Official Ex. No. EP-17

In the matter of Duke, Catawba 143

Staff _____

Applicant _____ IDENTIFIED ☒

Intervenor ☒ RECEIVED ☒

Conf. Off'r _____ REJECTED _____

Contractor _____

Other _____ DATE 5/7/84

Reporter M. Metzger

DUKE POWER COMPANY

CATAWBA NUCLEAR STATION

P. O. BOX 293

CLOVER, S. C. 29710

TELEPHONE: AREA 803
831-2282

May 7, 1980

Rock Hill Convalescent Center
1915 Ebenezer Road
Rock Hill, South Carolina 29730


Attention: Brenda Paris

Subject: Catawba Nuclear Station
Emergency Plan - Evacuation Times Estimates
for Areas Within the Exposure Emergency Planning Zone
(10 mile radius)
File No.: CN-134.10

Special facility evacuation times are based on the number of ambulances available within York County, initial travel time to the special facility, ambulance patient capacity, average travel distance for one round trip, plus added time for driver changes, refueling, and loading and unloading of people. These times are reported for the combined patient loads of all special facilities within your emergency planning area. This would include the evacuation of those patients requiring ambulance service from York General Hospital and Meadow Haven Nursing Center as well as Rock Hill Convalescent Center.

Within Area 10, the Special Facilities - Best Estimate - Evacuation Time is 1935 minutes, and the Adverse Weather - Evacuation Time is 2445 minutes.

These evacuation times have been reported to the NRC and discussed, at length, with local and state officials. Mutual agreement was reached that these values are adequate under a preliminary basis. For this reason this data should be used for information only purposes. Your cooperation in this matter is appreciated. Any questions you have may be directed to Mr. Rodney Kinard at 324-3128 ext. 2357.



J. W. Hampton, Manager
Catawba Nuclear Station

RDK/ga

✓cc: C. L. Thames - General Office