

OPERATING DATA REPORT

DOCKET NO. 50-482
 WOLF CREEK GENERATING STATION
 WOLF CREEK NUCLEAR OPERATING CORPORATION
 DATE 01-01-92
 COMPLETED BY M. Williams
 TELEPHONE 316-364-8831

OPERATING STATUS

1. Reporting Period: December, 1991 Gross Hours in Reporting Period: 744
 2. Currently Authorized Power Level(MWt): 3411 Max. Depend. Capacity(MWe-Net): 1135
 Design Electrical Rating (MWe-Net): 1170
 3. Power Level to Which Restricted (If Any)(MWe-Net): N/A
 4. Reasons for restriction (If Any): N/A
- | | This Month | Yr. to Date | Cumulative |
|---|--------------|-------------------|--------------------|
| 5. Number of Hours Reactor was Critical | <u>0.0</u> | <u>6,294.6</u> | <u>43,690.1</u> |
| 6. Reactor Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>339.8</u> |
| 7. Hours Generator on Line | <u>0.0</u> | <u>6,288.4</u> | <u>43,112.2</u> |
| 8. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>0.0</u> |
| 9. Gross Thermal Energy Generated (MWH) | <u>0</u> | <u>18,028,566</u> | <u>140,093,591</u> |
| 10. Gross Electrical Energy Generated (MWH) | <u>0</u> | <u>6,198,737</u> | <u>48,713,506</u> |
| 11. Net Electrical Energy Generated (MWH) | <u>0</u> | <u>5,858,613</u> | <u>46,455,471</u> |
| 12. Reactor Service Factor | <u>0</u> | <u>71.9</u> | <u>78.8</u> |
| 13. Reactor Availability Factor | <u>0</u> | <u>71.9</u> | <u>79.4</u> |
| 14. Unit Service Factor | <u>0</u> | <u>71.8</u> | <u>77.7</u> |
| 15. Unit Availability Factor | <u>0</u> | <u>71.8</u> | <u>77.7</u> |
| 16. Unit Capacity Factor (Using MDC) | <u>0</u> | <u>58.9</u> | <u>74.0</u> |
| 17. Unit Capacity Factor (Using Design MWe) | <u>0</u> | <u>57.2</u> | <u>71.6</u> |
| 18. Unit Forced Outage Rate | <u>100.0</u> | <u>9.6</u> | <u>4.9</u> |
19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each): N/A
 20. If Shut Down at End of Report Period, Estimated Date of Startup: January 13, 1992

Wolf Creek Generating Station
 Monthly Operating Report
 December 1991
 Page 2 of 5

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. 50-432
 WOLF CREEK GENERATING STATION
 WOLF CREEK NUCLEAR OPERATING CORPORATION
 DATE 01-01-92
 COMPLETED BY M. Williams
 TELEPHONE 316-364-8831

REPORT MONTH December, 1991

No	Date	TYPE	DURATION (HOURS)	REASON (1)	METHODS SHUTTING DOWN THE REACTOR OR REDUCING POWER(2)	CORRECTIVE ACTIONS/COMMENTS
		F: FORCED S: SCHEDULED				
3	911201	S	1.4	C	4	Continued refueling outage.
4	911204	F	742.6	H	4	Unit enters forced outage for resolution of motor operated valve issues.

SUMMARY: The unit remained in a refueling outage throughout the month. The unit entered day 76 of a scheduled 75 day outage December 4, 1991.

1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL
 B: MAINTENANCE OR TEST F: ADMINISTRATIVE 2. MANUAL SCRAM
 C: REFUELING G: OPERATIONAL ERROR (EXPLAIN) 3. AUTOMATIC SCRAM
 D: REGULATORY RESTRICTION H: OTHER (EXPLAIN) 4. CONTINUED
 5. REDUCED LOAD
 9. OTHER