

Georgia Power Company  
40 Inverness Center Parkway  
Post Office Box 1295  
Birmingham, Alabama 35201  
Telephone 205 877-7122

C. K. McCoy  
Vice President, Nuclear  
Vogtle Project



Georgia Power

the southern electric system

ELV-03446  
001174

February 13, 1992

Docket Nos. 50-424  
50-425

Director, Office of Resource Management  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Gentlemen:

**VOGTLE ELECTRIC GENERATING PLANT  
MONTHLY OPERATING REPORTS**

Enclosed are the January 1992 monthly operating reports for Vogtle Units 1 and 2. These reports are submitted in accordance with Technical Specification 6.8.1.5.

Also enclosed are revised pages only, which are for the November 1991, and December 1991, monthly operating reports for the Vogtle Electric Generating Plant (VEGP) Unit 1. These reports were previously submitted in accordance with Technical Specification 6.8.1.5 by our letters dated December 11, 1991 (ELV-03289) and January 13, 1992 (ELV-03365) respectively. Each revised entry is denoted by a change bar. These revisions to both the Gross and the Net Electrical Energy Generated were required to correct the erroneous readings taken from a replacement watt meter which had been installed during the Unit 1 refueling outage but not re-set to "zero" after testing.

Sincerely,

*C. K. McCoy*  
C. K. McCoy

CKM/JLL/gmb

**Enclosures:**

1. Monthly Operating Report - VEGP Unit 1
2. Monthly Operating Report - VEGP Unit 2
3. Challenges to PORV or Safety Valves - VEGP Units 1 and 2
4. Revised Monthly Operating Report for November - VEGP Unit 1
5. Revised Monthly Operating Report for December - VEGP Unit 1

xc: Georgia Power Company  
Mr. W. B. Shipman  
Mr. M. Sheibani  
NORMS

U. S. Nuclear Regulatory Commission  
Mr. S. D. Ebnetter, Regional Administrator  
Mr. D. S. Hood, Licensing Project Manager, NRR  
Mr. B. R. Bonser, Senior Resident Inspector, Vogtle  
Document Control Desk

9202190032 920213  
PDR ADDCK 05000424  
R PDR

19003

*JE24*