



**Entergy
Operations**

Entergy Operations, Inc.
Route 3, Box 137G
Russellville, AR 72801
Tel 501-964-3100

February 13, 1992

2CAN029202

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NFP-6
Schedule for Submitting Additional Information
Concerning the First Ten Year Inservice
Inspection Relief Requests (TAC No. M76001)

Gentlemen:

In letter 2CAN088915, August 31, 1989, Entergy Operations submitted relief requests for Arkansas Nuclear One, Unit 2 (ANO-2) for the first 10-year interval. These requests were for relief from certain ASME Section XI Inservice Inspection (ISI) requirements because only limited examinations could be performed. The relief requests were prepared in response to Violation 313/8826-02. The reason for the violation was that Entergy Operations was unaware, at the time the examinations were performed, that limited examinations required relief from the NRC. The NRC has subsequently requested additional information concerning these relief requests in letter dated September 10, 1991 (2CNA099102).

The ANO-2 ISI program at that time required the examination of certain selected welds. However, as recently discussed with the NRC Staff, where a weld was partially inaccessible for examination due to physical obstructions, the program only required documentation of this fact but did not require the recording of the necessary details to respond to the September 10, 1991, request. Specifically, on the partially-inaccessible welds, the percentage of Code-required examination coverage achieved during the first 10-year interval cannot be accurately determined. Therefore, Entergy Operations is unable to provide the requested information.

However, as a result of further discussions with the NRC Staff, it was agreed that Entergy Operations would provide a best estimate of the percentage of the Code-required coverage achieved during the first 10-year interval for the welds listed in the relief requests. These estimates will be submitted to the NRC by March 31, 1992.


2202190227 920213
PDR ADOCK 05000368
Q PDR

A047
1/0

U. S. NRC
February 13, 1992
Page 2

Should you have any questions regarding this issue, please contact me.

Very truly yours,



James J. Fisicaro
Director, Licensing

JJF/RWC/sjf

cc: Mr. Robert Martin
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One - ANO-1 & 2
Number 1, Nuclear Plant Road
Russellville, AR 72801

Mr. Thomas W. Alexion
NRR Project Manager, Region IV/ANO-1
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

Ms. Sheri Peterson
NRR Project Manager, Region IV/ANO-2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852