

ATTACHMENT IV

PROPOSED TECHNICAL SPECIFICATION CHANGES

EMERGENCY CORE COOLING SYSTEMS

3/4.5.5 REFUELING WATER STORAGE TANK

LIMITING CONDITION FOR OPERATION

3.5.5 The refueling water storage tank (RWST) shall be OPERABLE with:

- a. A minimum contained borated water volume of 394,000 gallons,
- b. A boron concentration of between 2400 and 2500 ppm of boron,
- c. A minimum solution temperature of 37°F, and
- d. A maximum solution temperature of 100°F

APPLICABILITY MODES 1, 2, 3, and 4

ACTION

With the RWST inoperable, restore the tank to OPERABLE status within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours

INSERT "A"

SURVEILLANCE REQUIREMENTS

4.5.5 The RWST shall be demonstrated OPERABLE:

- a. At least once per 7 days by:
 - 1) Verifying the contained borated water volume in the tank, and
 - 2) Verifying the boron concentration of the water.
- b. At least once per 24 hours by verifying the RWST temperature when the outside air temperature is either less than 37°F or greater than 100°F.

INSERT "A"

- a. With the RWST inoperable due to the boron concentration not being within the specified limits, restore the tank to OPERABLE status within 8 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With the RWST inoperable for reasons other than the boron concentration not being within the specified limits, restore the tank to OPERABLE status within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.