

INDUSTRIAL PRETREATMENT
QUARTERLY SELF-MONITORING RESULTS

Perry Nuclear Power Plant
10 Center Rd.
Perry, Ohio 44081

Permit No.: 1004911
Report Date: 8/25/95
Laboratory: Quanterra Inc.

Date of Sample: 8/8
Sample Location: Sewage Pump Station

Time of sample: 0920
Name of Sampler: Eric Smith


Laboratory Address: 1401 Shuffel Dr.
North Canton OH 44720

Date of Analysis: 8/10 to 8/22/95
Flow: 33,000 gpd

Name of Analyst: D. Nielsen

PARAMETER	SAMPLE TYPE	EPA METHOD	ANALYSIS DATE	ANALYSIS RESULT
COD	Composite	410.4	8/17 to 8/18	570 mg/L
BOD	Composite	405.1	8/9 to 8/14	None Detected
TSS	Composite	160.2	8/10	340 mg/L
Silver	Composite	200.7	8/16 to 8/22	None Detected
Mercury	Composite	245.1	8/16 to 8/17	None Detected
pH	Grab	150.1	8/8	8.4 s.u.
Oil/Grease Gravimetric	Grab	413.1	8/21 to 8/22	9.2 mg/L

I certify under penalty of law that I have personally examined and I am familiar with the information in this report and that, based on my inquiry of those persons immediately responsible for obtaining the information contained in this report, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.



Signature

8/15/95

Date

SR Vice President - Nuclear

Title

9509180276 950915
PDR ADOCK 05000440
R PDR

COPY

RPI-1103
Page: 93
Rev.: 0

Attachment 51

ENVIRONMENTAL SAMPLE LOG (RPI-1103-51)

Date/Time 8/30/95 1110

Sample Point: Sewage Lift Station

Parameter	Frequency Reg. / Admin	Limit		Ops Cond.	Action Notes	Results	Init.
		Reg	Admin				
Isotopic, µCi/ml	-/PE	-	<LLD	6	106	<u>none detected</u>	<u>X</u>
Oil & Grease, ppm	-/PE	-	<5	6	106	<u>N/A</u>	<u>-</u>

NOTE: Radioisotope LLD's are listed in Technical Specifications
Table 4.12.1-1.

Remarks: _____

Reviewed By: Angela 9/5/95