

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004
(412) 393-5206
(412) 643-8069 FAX

GEORGE S. THOMAS
Division Vice President
Nuclear Services
Nuclear Power Division

September 8, 1995


U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

Subject: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Completion of a Code Repair on Main Steam Drain Line
1½" SHPD-1-601-Q2

By letter dated May 4, 1995, Duquesne Light Company (DLC) requested relief for a temporary non-code repair on main steam drain line 1½" SHPD-1-601-Q2. This temporary repair was to be used until the next Unit 1 entry into Mode 5, when a code repair could be performed. The NRC provided written approval of this request by letter dated June 29, 1995 (TAC No. M92165).

A code repair was completed on main steam drain line 1½" SHPD-1-601-Q2 on August 27, 1995. The repair replaced the piping from the main steam header sockolet connection up to and including the degraded elbow. The integrity of the repair was verified during the system leakage examination, which was performed in accordance with the requirements of ASME Code Case N-416-1.

Sincerely,


George S. Thomas

c: Mr. L. W. Rossbach, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. D. S. Brinkman, Sr. Project Manager

100072

9509190098 950908
PDR ADOCK 05000334
P PDR

AD4710