

James A. FitzPatrick
Nuclear Power Plant
P.O. Box 41
Lycoming, New York 13093
*315 342.3840



**New York Power
Authority**

Harry P. Salmon, Jr.
Site Executive Officer

September 14, 1995
JAFF-95-0413

U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555

Attention: Document Control Desk
SUBJECT: OPERATING STATUS REPORT
Reference: DOCKET NO. 50-333

Dear Sir:

Enclosed please find the James A. FitzPatrick Nuclear Power Plant
Operating Status Report for the month of **August 1995**.

If there are any questions concerning this report, please contact
Russ Flagg, Performance Engineering, at (315) 349-6768.

Very truly yours,

HARRY P. SALMON, JR.

RF
HPS:RGF:rjh
Enclosure

CC: F. Edler *FD by Jir*
JAF Department Heads
White Plains Office
TS File
RMS, JAF

100133

9509190200 950831
PDR ADOCK 05000333
R PDR

JE24,1

**NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATING DATA REPORT**

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: SEPTEMBER 1995
COMPLETED BY: RUSSELL FLAGG
TELEPHONE: (315)349-6768

OPERATING STATUS

1. Unit Name: FITZPATRICK
2. Reporting Period: 950801 - 950831
3. Licensed Thermal Power (MWT): 2436
4. Nameplate Rating (Gross MWE): 883.0
5. Design Electrical Rating (Net MWE): 816.0
6. Maximum Dependable Capacity (Gross MWE) 808.7
7. Maximum Dependable Capacity (Net MWE) 779.7

NOTES:

8. If changes occur in capacity ratings (Items 3-7) since last report, give reasons:

9. Power level to which restricted, if any (Net MWE): _____
10. Reasons for restrictions, if any: _____

	THIS MONTH	YR-TO-DATE	CUMULATIVE
--	------------	------------	------------

24. Shutdowns scheduled over next 6 months (type, date, and duration of each):

25. If shutdown at end of report period, estimated date of startup: _____

26. Units in Test Status (prior to commercial operation):	FORECAST	ACHIEVED
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
AVERAGE DAILY UNIT POWER LEVEL

REPORT MONTH: AUGUST 1995

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: SEPTEMBER 1995
COMPLETED BY: RUSSELL FLAGG
TELEPHONE: (315)349-6768

DAY	NET AVERAGE DAILY POWER LEVEL	DAY	NET AVERAGE DAILY POWER LEVEL
1	764	17	765
2	768	18	765
3	771	19	780
4	768	20	784
5	767	21	777
6	771	22	769
7	792	23	771
8	794	24	769
9	792	25	771
10	790	26	772
11	788	27	773
12	774	28	777
13	778	29	773
14	780	30	780
15	778	31	791
16	773		

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
UNIT SHUTDOWNS REPORT

REPORT MONTH: AUGUST 1995

DOCKET NO.: 50-333
UNIT NAME: FITZPATRICK
DATE: SEPTEMBER 1995
COMPLETED BY: RUSSELL FLAGG
TELEPHONE: (315)349-6768

NO.	DATE	TYPE	D U H R O A U T R I S T I O N	R E A S O N	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT	S Y C S O T D E E M	C O M C P O D E N E N T	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE

1
F: FORCED
S: SCHEDULED

2
REASON:
A. EQUIPMENT FAILURE (EXPLAIN)
B. MAINTENANCE OR TEST
C. REFUELING
D. REGULATORY RESTRICTION
E. OPERATOR TRAINING AND LICENSE EXAMINATION
F. ADMINISTRATIVE
G. OPERATIONAL ERROR (EXPLAIN)
H. OTHER (EXPLAIN)

3
METHOD:
1. MANUAL
2. MANUAL SCRAM
3. AUTOMATIC SCRAM
4. CONTINUED
5. REDUCED LOAD
9. OTHER

4
EXHIBIT G -INSTRUCTIONS
FOR PREPARATION OF DATA ENTRY
SHEETS FOR LICENSEE EVENT
REPORT (LER) FILE (NUREG-0161)

NEW YORK POWER AUTHORITY
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
NARRATIVE SUMMARY OF OPERATING EXPERIENCE

REPORT MONTH: AUGUST 1995

DOCKET NO.:	50-333
UNIT NAME:	FITZPATRICK
DATE:	SEPTEMBER 1995
COMPLETED BY:	RUSSELL FLAGG
TELEPHONE:	(315)349-6768

The FitzPatrick Plant remained in service throughout the reporting period. Plant output was reduced by 10 MWe on 08/17 and 08/18 to maintain condenser vacuum, due to high lake temperature.