

=====

ANNUAL REPORT OF SAFETY VALVE

AND RELIEF VALVE

FAILURES AND CHALLENGES

=====

This annual report is submitted in the January Monthly Operating Report in response to requirements implemented as a result of NUREG-0737, Item II.K.3.3 and to fulfill ANO-2 Technical Specification reporting requirement 6.9.1.5.C.

ANO-2 does not have an electromatic relief valve (ERV); therefore, no challenges to the primary system code safeties occurred in 1991.

No challenges to the ANO-1 primary system code safeties or ERV occurred in 1991.