



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379

J. L. Wilson
Vice President, Sequoyah Nuclear Plant

February 18, 1992

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:


In the Matter of)	Docket Nos. 50-327
Tennessee Valley Authority)	50-328

SEQUOYAH NUCLEAR PLANT (SQN) - JANUARY 1992 MONTHLY OPERATING REPORT

Enclosed is the January 1992 Monthly Operating Report as required by SQN
Technical Specification 6.9.1.10.

If you have any questions concerning this matter, please call
M. A. Cooper at (615) 843-8924.

Sincerely,


J. L. Wilson

Enclosure
cc: See page 2

9202210343 920131
PDR ADDCK 05000327
R PDR

JE24 1/1

U.S. Nuclear Regulatory Commission

Page 2

February 18, 1992

cc (Enclosure):

NRC Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30389

Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. Ted Marston, Director
Electric Power Research Institute
P.O. Box 10412
Palo Alto, California 94304

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37379

Regional Administration
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. F. Yost, Director Research Services
Utility Data Institute
1700 K Street, NW, Suite 400
Washington, D.C. 20006

TENNESSEE VALLEY AUTHORITY

NUCLEAR POWER GROUP
SEQUOYAH NUCLEAR PLANT

MONTHLY OPERATING REPORT
TO THE
NUCLEAR REGULATORY COMMISSION
JANUARY 1992

UNIT 1

DOCKET NUMBER 50-327

LICENSE NUMBER DPR-77

UNIT 2

DOCKET NUMBER 50-328

LICENSE NUMBER DPR-79

OPERATIONAL SUMMARY
JANUARY 1992

UNIT 1

Unit 1 generated 874,638 megawatthours (MWh) (gross) electrical power during January with a capacity factor of 101.17 percent. Unit 1 was operating at approximately 100 percent reactor power at the end of January.

UNIT 2

Unit 2 generated 862,686 MWh (gross) electrical power during January with a capacity factor of 99.79 percent. Unit 2 operated at 100 percent reactor power level until January 28, 1992, at 1548 (EST), when Unit 2 entered coastdown to the Unit 2 Cycle 5 refueling outage that is scheduled to begin March 13, 1992. Unit 2 was operating at approximately 96 percent reactor power level at the end of January.

POWER-OPERATED RELIEF VALVES (PORV) AND SAFETY VALVES SUMMARY

There were no challenges to PORVs or safety valves in January.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-327 UNIT No. One DATE: 02-05-92
 COMPLETED BY: T. J. Hollomon TELEPHONE: (615) 843-7528
 MONTH: JANUARY 1992

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>1123</u>	17	<u>1144</u>
2	<u>1126</u>	18	<u>1146</u>
3	<u>1126</u>	19	<u>1147</u>
4	<u>1126</u>	20	<u>1148</u>
5	<u>1127</u>	21	<u>1148</u>
6	<u>1128</u>	22	<u>1148</u>
7	<u>1126</u>	23	<u>1151</u>
8	<u>1127</u>	24	<u>1149</u>
9	<u>1128</u>	25	<u>1148</u>
10	<u>1131</u>	26	<u>1149</u>
11	<u>1121</u>	27	<u>1149</u>
12	<u>1132</u>	28	<u>1149</u>
13	<u>1140</u>	29	<u>1148</u>
14	<u>1142</u>	30	<u>1153</u>
15	<u>1142</u>	31	<u>1150</u>
16	<u>1142</u>		

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-328 UNIT No. Two DATE: 02-05-92
 COMPLETED BY: T. J. Hollomon TELEPHONE: (615) 843-7528
 MONTH: JANUARY 1992

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>1125</u>	17	<u>1125</u>
2	<u>1124</u>	18	<u>1126</u>
3	<u>1125</u>	19	<u>1125</u>
4	<u>1126</u>	20	<u>1124</u>
5	<u>1126</u>	21	<u>1125</u>
6	<u>1126</u>	22	<u>1126</u>
7	<u>1127</u>	23	<u>1127</u>
8	<u>1127</u>	24	<u>1125</u>
9	<u>1126</u>	25	<u>1127</u>
10	<u>1125</u>	26	<u>1127</u>
11	<u>1125</u>	27	<u>1125</u>
12	<u>1126</u>	28	<u>1118</u>
13	<u>1125</u>	29	<u>1105</u>
14	<u>1125</u>	30	<u>1093</u>
15	<u>1125</u>	31	<u>1089</u>
16	<u>1125</u>		

OPERATING DATA REPORT

DOCKET NO.	50-327
DATE	Feb. 5, 1992
COMPLETED BY	T. J. Hollomon
TELEPHONE	(615) 843-7528

OPERATING STATUS

- | | |
|---|-------------------|
| 1. Unit Name: | Sequoyah Unit One |
| 2. Reporting Period: | January 1992 |
| 3. Licensed Thermal Power (Mwt): | 3411.0 |
| 4. Nameplate Rating (Gross MWe): | 1220.6 |
| 5. Design Electrical Rating (Net MWe): | 1136.0 |
| 6. Maximum Dependable Capacity (Gross MWe): | 1162.0 |
| 7. Maximum Dependable Capacity (Net MWe): | 1122.0 |
| 8. If Changes Occur in Capacity Ratings (Item Numbers 3 Through 7) Since Last Report, Give Reasons: | |

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons for Restrictions, If Any: N/A

	This Month	Yr-to-Date	Cumulative
11. Hours in Reporting Period	744	744	92,809
12. Number of Hours Reactor Was Critical	744.0	744.0	47,698.0
13. Reactor Reserve Shutdown Hours	0	0	0
14. Hours Generator On-Line	744.0	744.0	46,615.1
15. Unit Reserve Shutdown Hours	0.0	0	0
16. Gross Thermal Energy Generated (MWH)	2,519,742.4	2,519,742.4	152,132,276
17. Gross Electrical Energy Generated (MWH)	874,638	874,638	51,542,134
18. Net Electrical Energy Generated (MWH)	845,894	845,894	49,410,628
19. Unit Service Factor	100.0	100.0	50.2
20. Unit Availability Factor	100.0	100.0	50.2
21. Unit Capacity Factor (Using MDC Net)	101.3	101.3	47.5
22. Unit Capacity Factor (Using DER Net)	99.0	99.0	46.4
23. Unit Forced Outage Rate	0.0	0.0	41.1
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _____

OPERATING DATA REPORT

DOCKET NO. 50-328
 DATE Feb. 5, 1992
 COMPLETED BY T. J. Hollomon
 TELEPHONE (615) 843-7528

OPERATING STATUS

1. Unit Name: Sequoyah Unit Two
2. Reporting Period: January 1992
3. Licensed Thermal Power (MWt): 3411.0
4. Nameplate Rating (Gross MWe): 1220.6
5. Design Electrical Rating (Net MWe): 1148.0
6. Maximum Dependable Capacity (Gross MWe): 1162.0
7. Maximum Dependable Capacity (Net MWe): 1122.0
8. If Changes Occur in Capacity Ratings (Item Numbers 3 Through 7) Since Last Report, Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr-to-Date	Cumulative
11. Hours in Reporting Period	744	744	84,769
12. Number of Hours Reactor Was Critical	744.0	744.0	49,752
13. Reactor Reserve Shutdown Hours	0	0	0
14. Hours Generator On-Line	744.0	744.0	48,787.2
15. Unit Reserve Shutdown Hours	0.0	0	0
16. Gross Thermal Energy Generated (MWH)	2,526,794.1	2,526,794.1	153,454,107
17. Gross Electrical Energy Generated (MWH)	862,686	862,686	52,020,977
18. Net Electrical Energy Generated (MWH)	833,522	833,522	49,778,486
19. Unit Service Factor	100.0	100.0	57.6
20. Unit Availability Factor	100.0	100.0	57.6
21. Unit Capacity Factor (Using MDC Net)	99.9	99.9	52.3
22. Unit Capacity Factor (Using DER Net)	97.6	97.6	51.2
23. Unit Forced Outage Rate	0.0	0.0	35.7

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

Unit 2 Cycle 5 refueling outage is scheduled to begin March 13, 1992, and is currently scheduled as a 65-day outage.

25. If Shut Down At End Of Report Period, Estimated Date of Startup: N/A

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH: January 1992DOCKET NO: 50-327UNIT NAME: OneDATE: 02/05/92COMPLETED BY: L. C. HollomanTELEPHONE: (515) 843-7528

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
									No shutdown or power reductions greater than 10 percent for a 24-hour period to report.

¹F: Forced
S: Scheduled

²Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training and License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Continuation of Existing Outage
5-Reduction
9-Other

⁴Exhibit G-Instructions
for Preparation of Data
Entry sheets for Licensee
Event Report (LER) File
(NUREG-1[22])

⁵Exhibit I-Same Source

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH: January 1992DOCKET NO: 50-328UNIT NAME: TwoDATE: 02/05/92COMPLETED BY: T. J. HollomanTELEPHONE: (615) 843-7528

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
									No shutdown or power reductions greater than 10 percent for a 24-hour period to report.

¹F: Forced
S: Scheduled

²Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training and License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Continuation of Existing Outage
5-Reduction
9-Other

⁴Exhibit G-Instructions
for Preparation of Data
Entry sheets for Licensee
Event Report (LER) File
(NUREG-1122)

⁵Exhibit I-Same Source