

ATTACHMENT 2

LIMERICK GENERATING STATION
UNITS 1 AND 2

Docket Nos.
50-352
50-353

License Nos.
NPF-39
NPF-85

TECHNICAL SPECIFICATIONS CHANGE REQUEST
NO. 95-15-0

AFFECTED PAGES

UNIT 1

xiii
3/4 6-48
3/4 6-49
3/4 6-50
3/4 6-51
3/4 6-51a
B 3/4 6-6

UNIT 2

xiii
3/4 6-48
3/4 6-49
3/4 6-50
3/4 6-51
3/4 6-51a
B 3/4 6-6

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>CONTAINMENT SYSTEMS (Continued)</u>	
3/4.6.4 VACUUM RELIEF	
Suppression Chamber - Drywell Vacuum Breakers.....	3/4 6-44
3/4.6.5 SECONDARY CONTAINMENT	
Reactor Enclosure Secondary Containment Integrity.....	3/4 6-46
Refueling Area Secondary Containment Integrity.....	3/4 6-47
Reactor Enclosure Secondary Containment Automatic Isolation Valves.....	3/4 6-48
Table 3.6.5.2.1-1 Reactor Enclosure Secondary Containment Ventilation System Automatic Isolation Valves.....	3/4 6-49
Refueling Area Secondary Containment Automatic Isolation Valves.....	3/4 6-50
Table 3.6.5.2.2-1 Refueling Area Secondary Containment Ventilation System Automatic Isolation Valves.....	3/4 6-51
Standby Gas Treatment System - Common System.....	3/4 6-52
Reactor Enclosure Recirculation System.....	3/4 6-55
3/4.6.6 PRIMARY CONTAINMENT ATMOSPHERE CONTROL	
Primary Containment Hydrogen Recombiner Systems.....	3/4 6-57
Drywell Hydrogen Mixing System.....	3/4 6-58
Drywell and Suppression Chamber Oxygen Concentration....	3/4 6-59
<u>3/4.7 PLANT SYSTEMS</u>	
3/4.7.1 SERVICE WATER SYSTEMS	
Residual Heat Removal Service Water System - Common System.....	3/4 7-1
Emergency Service Water System - Common System.....	3/4 7-3
Ultimate Heat Sink.....	3/4 7-5

CONTAINMENT SYSTEMS

REACTOR ENCLOSURE SECONDARY CONTAINMENT AUTOMATIC ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.6.5.2.1 The reactor enclosure secondary containment ventilation system automatic isolation valves shown in Table 3.6.5.2.1 shall be OPERABLE with isolation times less than or equal to the times shown in Table 3.6.5.2.1.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3.

ACTION:

DELETE

ADD

With one or more of the reactor secondary containment ventilation system automatic isolation valves shown in Table 3.6.5.2.1 inoperable, maintain at least one isolation valve OPERABLE in each affected penetration that is open and within 8 hours either:

- Restore the inoperable valves to OPERABLE status, or
- Isolate each affected penetration by use of at least one deactivated valve secured in the isolation position, or
- Isolate each affected penetration by use of at least one closed manual valve, blind flange or slide gate damper.

Otherwise, in OPERATIONAL CONDITION 1, 2, or 3, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

SURVEILLANCE REQUIREMENTS

4.6.5.2.1 Each reactor enclosure secondary containment ventilation system automatic isolation valve shown in Table 3.6.5.2.1 shall be demonstrated OPERABLE:

DELETE

- Prior to returning the valve to service after maintenance, repair or replacement work is performed on the valve or its associated actuator, control or power circuit by cycling the valve through at least one complete cycle of full travel and verifying the specified isolation time.
- At least once per 24 months by verifying that on a containment isolation test signal each isolation valve actuates to its isolation position.
- By verifying the isolation time to be within its limit at least once per 92 days.

TABLE 3.6.5.2.1-1

REACTOR ENCLOSURE SECONDARY CONTAINMENT VENTILATION SYSTEM
AUTOMATIC ISOLATION VALVES

<u>REACTOR ENCLOSURE (ZONE 1)</u>		<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNALS^(a)</u>
<u>VALVE FUNCTION</u>			
1. Reactor Enclosure Ventilation Supply Valve HV-76-107		5	B,H,S,U
2. Reactor Enclosure Ventilation Supply Valve HV-76-108		5	B,H,S,U
3. Reactor Enclosure Ventilation Exhaust Valve HV-76-157		5	B,H,S,U
4. Reactor Enclosure Ventilation Exhaust Valve HV-76-158		5	B,H,S,U
5. Reactor Enclosure Equipment Compartment Exhaust Valve HV-76-141		5	B,H,S,U
6. Reactor Enclosure Equipment Compartment Exhaust Valve HV-76-142		5	B,H,S,U
7. Drywell Purge Exhaust Valve HV-76-030		5	B,H,S,U,R,T
8. Drywell Purge Exhaust Valve HV-76-031		5	B,H,S,U,R,T
9. Drywell Purge Exhaust Inboard Valve HV-57-214 (Unit 2)		5	B,H,S,U,W,R,T
10. Drywell Purge Exhaust Outboard Valve HV-57-215 (Unit 2)		6	B,H,S,U,W,R,T
11. Suppression Pool Purge Exhaust Inboard Valve HV-57-204 (Unit 2)		5	B,H,S,U,W,R,T
12. Suppression Pool Purge Exhaust Outboard Valve HV-57-212 (Unit 2)		6	B,H,S,U,W,R,T

THE INFORMATION FROM THIS TECHNICAL
 SPECIFICATIONS SECTION HAS BEEN RELOCATED
 TO THE UFSAR.

ADD

DELETE

(a) See Specification 3.3.2, Table 3.3.2-1, for isolation signals that operate
 each automatic valve.

CONTAINMENT SYSTEMS

REFUELING AREA SECONDARY CONTAINMENT AUTOMATIC ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.6.5.2.2 The refueling area secondary containment ventilation system automatic isolation valves shown in Table 3.6.5.2.2-1 shall be OPERABLE with isolation times less than or equal to the times shown in Table 3.6.5.2.2-1.

APPLICABILITY: OPERATIONAL CONDITION *.

ACTION:

With one or more of the refueling area secondary containment ventilation system automatic isolation valves shown in Table 3.6.5.2.2-1 inoperable, maintain at least one isolation valve OPERABLE in each affected penetration that is open and within 8 hours either:

- Restore the inoperable valves to OPERABLE status, or
- Isolate each affected penetration by use of at least one deactivated valve secured in the isolation position, or
- Isolate each affected penetration by use of at least one closed manual valve, blind flange or slide gate damper.

Otherwise, in OPERATIONAL CONDITION *, suspend handling of irradiated fuel in the refueling area secondary containment, CORE ALTERATIONS and operations with a potential for draining the reactor vessel. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.6.5.2.2 Each refueling area secondary containment ventilation system automatic isolation valve shown in Table 3.6.5.2.2-1 shall be demonstrated OPERABLE:

- Prior to returning the valve to service after maintenance, repair or replacement work is performed on the valve or its associated actuator, control or power circuit by cycling the valve through at least one complete cycle of full travel and verifying the specified isolation time.
- At least once per 24 months by verifying that on a containment isolation test signal each isolation valve actuates to its isolation position.
- By verifying the isolation time to be within its limit at least once per 92 days.

*Required when (1) irradiated fuel is being handled in the refueling area secondary containment, or (2) during CORE ALTERATIONS, or (3) during operations with a potential for draining the reactor vessel with the vessel head removed and fuel in the vessel.

TABLE 3.6.5-2.2-1

REFUELING AREA SECONDARY CONTAINMENT VENTILATION SYSTEM
AUTOMATIC ISOLATION VALVES

<u>REFUELING AREA (ZONE III)</u>		<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNALS^(a)</u>
<u>VALVE FUNCTION</u>			
1. Refueling Area Ventilation Supply Valve HV-76-117 (Unit 1)		5	R,T
2. Refueling Area Ventilation Supply Valve HV-76-118 (Unit 1)		5	R,T
3. Refueling Area Ventilation Exhaust Valve HV-76-167 (Unit 1)		5	R,T
4. Refueling Area Ventilation Exhaust Valve HV-76-168 (Unit 1)		5	R,T
5. Refueling Area Ventilation Supply Valve HV-76-217 (Unit 2)		5	R,T
6. Refueling Area Ventilation Supply Valve HV-76-218 (Unit 2)		5	R,T
7. Refueling Area Ventilation Exhaust Valve HV-76-267 (Unit 2)		5	R,T
8. Refueling Area Ventilation Exhaust Valve HV-76-268 (Unit 2)		5	R,T
9. Drywell Purge Exhaust Valve HV-76-030		5	B,H,S,U,R,T
10. Drywell Purge Exhaust Valve HV-76-031		5	B,H,S,U,R,T
11. Drywell Purge Exhaust Inboard Valve HV-57-114 (Unit 1)		5	B,H,S,U,W,R,T
12. Drywell Purge Exhaust Outboard Valve HV-57-115 (Unit 1)		6	B,H,S,U,W,R,T
13. Suppression Pool Purge Exhaust Inboard Valve HV-57-104 (Unit 1)		5	B,H,S,U,W,R,T
14. Suppression Pool Purge Exhaust Outboard Valve HV-57-112 (Unit 1)		6	B,H,S,U,W,R,T

DELETE

THE INFORMATION FROM THIS TECHNICAL SPECIFICATIONS SECTION HAS BEEN RELOCATED TO THE UFSAR.

ADD

TABLE 3.6-5.2.2-1 (Continued)
REFUELING AREA SECONDARY CONTAINMENT VENTILATION SYSTEM
AUTOMATIC ISOLATION VALVES

REFUELING AREA (ZONE III)	MAXIMUM ISOLATION TIME (Seconds)	ISOLATION SIGNALS ^(a)
VALVE FUNCTION		
15. Drywell-Purge Exhaust Inboard Valve HV-57-214 (Unit 2)	1	B,H,S,U,W,R,T
16. Drywell Purge Exhaust Outboard Valve HV-57-215 (Unit 2)	6	B,H,S,U,W,R,T
17. Suppression Pool Purge Exhaust Inboard Valve HV-57-204 (Unit 2)	5	B,H,S,U,W,R,T
18. Suppression Pool Purge Exhaust Outboard Valve HV-57-212 (Unit 2)	6	B,H,S,U,W,R,T

THE INFORMATION FROM THIS TECHNICAL SPECIFICATIONS SECTION HAS BEEN RELOCATED TO THE UFSAR.

ADD

DELETE

(a) See Specification 3.3.2, Table 3.3.2-1, for isolation signals that operate each automatic isolation valve.

CONTAINMENT SYSTEMSBASES3/4.6.5 SECONDARY CONTAINMENT (Continued)

The field tests for bypass leakage across the SGT5 charcoal adsorber and HEPA filter banks are performed at a flow rate of $3000 \pm 10\%$ cfm. This flow rate corresponds to the maximum overall three zone inleakage rate of 3264 cfm.

The SGT5 filter train pressure drop is a function of air flow rate and filter conditions. Surveillance testing is performed using either the SGT5 or drywell purge fans to provide operating convenience.

Each reactor enclosure secondary containment zone and refueling area secondary containment zone is tested independently to verify the design leak tightness. A design leak tightness of 1250 cfm or less for each reactor enclosure and 764 cfm or less for the refueling area at a 0.25 inch of vacuum water gage will ensure that containment integrity is maintained at an acceptable level if all zones are connected to the SGT5 at the same time.

The post-LOCA offsite dose analysis assumes a reactor enclosure secondary containment post-draw down leakage rate of 1250 cfm and certain post-accident X/Q values. While the post-accident X/Q values represent a statistical interpretation of historical meteorological data, the highest ground level wind speed which can be associated with these values is 7 mph (Pasquill-Gifford stability Class G for a ground level release). Therefore, the surveillance requirement assures that the reactor enclosure secondary containment is verified under meteorological conditions consistent with the assumptions utilized in the design basis analysis. Reactor Enclosure Secondary Containment leakage tests that are successfully performed at wind speeds in excess of 7 mph would also satisfy the leak rate surveillance requirements, since it shows compliance with more conservative test conditions.

3/4.6.6 PRIMARY CONTAINMENT ATMOSPHERE CONTROL

The OPERABILITY of the systems required for the detection and control of hydrogen combustible mixtures of hydrogen and oxygen ensures that these systems will be available to maintain the hydrogen concentration within the primary containment below the lower flammability limit during post-LOCA conditions. The primary containment hydrogen recombiner is provided to maintain the oxygen concentration below the lower flammability limit. The combustible gas analyzer is provided to continuously monitor, both during normal operations and post-LOCA, the hydrogen and oxygen concentrations in the primary containment. The primary containment atmospheric mixing system is provided to ensure adequate mixing of the containment atmosphere to prevent localized accumulations of hydrogen and oxygen from exceeding the lower flammability limit. The hydrogen control system is consistent with the recommendations of Regulatory Guide 1.7, "Control of Combustible Gas Concentrations in Containment Following a LOCA," March 1971.

The Reactor Enclosure Secondary Containment Automatic Isolation Valves and Refueling Area Secondary Containment Automatic Isolation Valves can be found in the UFSAR. ADD

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>CONTAINMENT SYSTEMS (Continued)</u>	
3/4.6.4 VACUUM RELIEF	
Suppression Chamber - Drywell Vacuum Breakers.....	3/4 6-44
3/4.6.5 SECONDARY CONTAINMENT	
Reactor Enclosure Secondary Containment Integrity.....	3/4 6-46
Refueling Area Secondary Containment Integrity.....	3/4 6-47
Reactor Enclosure Secondary Containment Automatic Isolation Valves.....	3/4 6-48
Table 3.6.5.2.1-1 Reactor Enclosure Secondary Containment Ventilation System Automatic Isolation Valves.....	3/4 6-49
Refueling Area Secondary Containment Automatic Isolation Valves.....	3/4 6-50
Table 3.6.5.2.2-1 Refueling Area Secondary Containment Ventilation System Automatic Isolation Valves.....	3/4 6-51
Standby Gas Treatment System - Common System.....	3/4 6-52
Reactor Enclosure Recirculation System.....	3/4 6-55
3/4.6.6 PRIMARY CONTAINMENT ATMOSPHERE CONTROL	
Primary Containment Hydrogen Recombiner Systems.....	3/4 6-57
Drywell Hydrogen Mixing System.....	3/4 6-58
Drywell and Suppression Chamber Oxygen Concentration....	3/4 6-59
<u>3/4.7 PLANT SYSTEMS</u>	
3/4.7.1 SERVICE WATER SYSTEMS	
Residual Heat Removal Service Water System - Common System.....	3/4 7-1
Emergency Service Water System - Common System.....	3/4 7-3
Ultimate Heat Sink.....	3/4 7-5

CONTAINMENT SYSTEMS

REACTOR ENCLOSURE SECONDARY CONTAINMENT AUTOMATIC ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.6.5.2.1 The reactor enclosure secondary containment ventilation system automatic isolation valves shown in Table 3.6.5.2.1-1 shall be OPERABLE with isolation times less than or equal to the times shown in Table 3.6.5.2.1-1.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3.

ACTION:

With one or more of the reactor secondary containment ventilation system automatic isolation valves shown in Table 3.6.5.2.1-1 inoperable, maintain at least one isolation valve OPERABLE in each affected penetration that is open and within 8 hours either:

- Restore the inoperable valves to OPERABLE status, or
- Isolate each affected penetration by use of at least one deactivated valve secured in the isolation position, or
- Isolate each affected penetration by use of at least one closed manual valve, blind flange or slide gate damper.

Otherwise, in OPERATIONAL CONDITION 1, 2, or 3, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

SURVEILLANCE REQUIREMENTS

4.6.5.2.1 Each reactor enclosure secondary containment ventilation system automatic isolation valve shown in Table 3.6.5.2.1-1 shall be demonstrated OPERABLE:

- Prior to returning the valve to service after maintenance, repair or replacement work is performed on the valve or its associated actuator, control or power circuit by cycling the valve through at least one complete cycle of full travel and verifying the specified isolation time.
- At least once per 24 months by verifying that on a containment isolation test signal each isolation valve actuates to its isolation position.
- By verifying the isolation time to be within its limit at least once per 92 days.

TABLE 3.6.5.2.1-1
REACTOR ENCLOSURE SECONDARY CONTAINMENT VENTILATION SYSTEM
AUTOMATIC ISOLATION VALVES

<u>REACTOR ENCLOSURE (ZONE II)</u>		<u>MAXIMUM</u> <u>ISOLATION TIME</u> <u>(Seconds)</u>	<u>ISOLATION</u> <u>SIGNALS^(a)</u>
<u>VALVE FUNCTION</u>			
1. Reactor Enclosure Ventilation Supply Valve HV-76-207		5	B,H,S,U
2. Reactor Enclosure Ventilation Supply Valve HV-76-208		5	B,H,S,U
3. Reactor Enclosure Ventilation Exhaust Valve HV-76-257		5	B,H,S,U
4. Reactor Enclosure Ventilation Exhaust Valve HV-76-258		5	B,H,S,U
5. Reactor Enclosure Equipment Compartment Exhaust Valve HV-76-241		5	B,H,S,U
6. Reactor Enclosure Equipment Compartment Exhaust Valve HV-76-242		5	B,H,S,U
7. Drywell Purge Exhaust Valve HV-76-030		5	B,H,S,U,R,T
8. Drywell Purge Exhaust Valve HV-76-031		5	B,H,S,U,R,T
9. Drywell Purge Exhaust Inboard Valve HV-57-114 (Unit 1)		5	B,H,S,U,W,R,T
10. Drywell Purge Exhaust Outboard Valve HV-57-115 (Unit 1)		6	B,H,S,U,W,R,T
11. Suppression Pool Purge Exhaust Inboard Valve HV-57-104 (Unit 1)		5	B,H,S,U,W,R,T
12. Suppression Pool Purge Exhaust Outboard Valve HV-57-112 (Unit 1)		6	B,H,S,U,W,R,T

THE INFORMATION FROM THIS TECHNICAL SPECIFICATIONS SECTION HAS BEEN RELOCATED TO THE UFSAR.

ADD

DELETE

^(a) See Specification 3.3.2, Table 3.3.2-1, for isolation signals that operate each automatic valve.

CONTAINMENT SYSTEMS

REFUELING AREA SECONDARY CONTAINMENT AUTOMATIC ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.6.5.2.2 The refueling area secondary containment ventilation system automatic isolation valves shown in Table 3.6.5.2.2-1 shall be OPERABLE with isolation times less than or equal to the times shown in Table 3.6.5.2.2-1.

APPLICABILITY: OPERATIONAL CONDITION *.

ACTION:

With one or more of the refueling area secondary containment ventilation system automatic isolation valves shown in Table 3.6.5.2.2-1 inoperable, maintain at least one isolation valve OPERABLE in each affected penetration that is open and within 8 hours either:

- a. Restore the inoperable valves to OPERABLE status, or
- b. Isolate each affected penetration by use of at least one deactivated valve secured in the isolation position, or
- c. Isolate each affected penetration by use of at least one closed manual valve, blind flange or slide gate damper.

Otherwise, in OPERATIONAL CONDITION *, suspend handling of irradiated fuel in the refueling area secondary containment, CORE ALTERATIONS and operations with a potential for draining the reactor vessel. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.6.5.2.2 Each refueling area secondary containment ventilation system automatic isolation valve shown in Table 3.6.5.2.2-1 shall be demonstrated OPERABLE:

- a. Prior to returning the valve to service after maintenance, repair or replacement work is performed on the valve or its associated actuator, control or power circuit by cycling the valve through at least one complete cycle of full travel and verifying the specified isolation time.
- b. At least once per 24 months by verifying that on a containment isolation test signal each isolation valve actuates to its isolation position.
- c. By verifying the isolation time to be within its limit at least once per 92 days.

*Required when (1) irradiated fuel is being handled in the refueling area secondary containment, or (2) during CORE ALTERATIONS, or (3) during operations with a potential for draining the reactor vessel with the vessel head removed and fuel in the vessel.

TABLE 3.6.5.2.2-1

REFUELING AREA SECONDARY CONTAINMENT VENTILATION SYSTEM
AUTOMATIC ISOLATION VALVES

<u>REFUELING AREA (ZONE III)</u>		<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNALS^(a)</u>
<u>VALVE FUNCTION</u>			
1. Refueling Area Ventilation Supply Valve HV-76-117 (Unit 1)		5	R,T
2. Refueling Area Ventilation Supply Valve HV-76-118 (Unit 1)		5	R,T
3. Refueling Area Ventilation Exhaust Valve HV-76-167 (Unit 1)		5	R,T
4. Refueling Area Ventilation Exhaust Valve HV-76-168 (Unit 1)		5	R,T
5. Refueling Area Ventilation Supply Valve HV-76-217 (Unit 2)		5	R,T
6. Refueling Area Ventilation Supply Valve HV-76-218 (Unit 2)		5	R,T
7. Refueling Area Ventilation Exhaust Valve HV-76-267 (Unit 2)		5	R,T
8. Refueling Area Ventilation Exhaust Valve HV-76-268 (Unit 2)		5	R,T
9. Drywell Purge Exhaust Valve HV-76-030		5	B,H,S,U,R,T
10. Drywell Purge Exhaust Valve HV-76-031		5	B,H,S,U,R,T
11. Drywell Purge Exhaust Inboard Valve HV-57-114 (Unit 1)		5	B,H,S,U,W,R,T
12. Drywell Purge Exhaust Outboard Valve HV-57-115 (Unit 1)		6	B,H,S,U,W,R,T
13. Suppression Pool Purge Exhaust Inboard Valve HV-57-104 (Unit 1)		5	B,H,S,U,W,R,T
14. Suppression Pool Purge Exhaust Outboard Valve HV-57-112 (Unit 1)		6	B,H,S,U,W,R,T

THE INFORMATION FROM THIS TECHNICAL SPECIFICATIONS SECTION HAS BEEN RELOCATED TO THE UFSAR.

DELETE

ADD

TABLE 3.6.5.2.2-1 (Continued)

REFUELING AREA SECONDARY CONTAINMENT VENTILATION SYSTEM
AUTOMATIC ISOLATION VALVES

REFUELING AREA (ZONE III)

VALVE FUNCTION

MAXIMUM
ISOLATION TIME
(Seconds)

ISOLATION
SIGNALS^(a)

15. Drywell Purge Exhaust Inboard Valve HV-57-214 (Unit 2)	5	B,H,S,U,W,R,T
16. Drywell Purge Exhaust Outboard Valve HV-57-215 (Unit 2)	6	B,H,S,U,W,R,T
17. Suppression Pool Purge Exhaust Inboard Valve HV-57-204 (Unit 2)	5	B,H,S,U,W,R,T
18. Suppression Pool Purge Exhaust Outboard Valve HV-57-212 (Unit 2)	6	B,H,S,U,W,R,T

THE INFORMATION FROM THIS TECHNICAL
SPECIFICATIONS SECTION HAS BEEN RELOCATED
TO THE UFSAR.

ADD

DELETE

(a) See Specification 3.3.2, Table 3.3.2-1, for isolation signals that
operate each automatic isolation valve.

CONTAINMENT SYSTEMS

BASES

SECONDARY CONTAINMENT (Continued)

The SGTS fans are sized for three zones and therefore, when aligned to a single zone or two zones, will have excess capacity to more quickly drawdown the affected zones. There is no maximum flow limit to individual zones or pairs of zones and the air balance and drawdown time are verified when all three zones are connected to the SGTS.

The three zone air balance verification and drawdown test will be done after any major system alteration, which is any modification which will have an effect on the SGTS flowrate such that the ability of the SGTS to drawdown the reactor enclosure to greater than or equal to 0.25 inch of vacuum water gage in less than or equal to 126 seconds could be affected.

The field tests for bypass leakage across the SGTS charcoal adsorber and HEPA filter banks are performed at a flow rate of $3000 \pm 10\%$ cfm. This flow rate corresponds to the maximum overall three zone inleakage rate of 3264 cfm.

The SGTS filter train pressure drop is a function of air flow rate and filter conditions. Surveillance testing is performed using either the SGTS or drywell purge fans to provide operating convenience.

Each reactor enclosure secondary containment zone and refueling area secondary containment zone is tested independently to verify the design leak tightness. A design leak tightness of 1250 cfm or less for each reactor enclosure and 764 cfm or less for the refueling area at a 0.25 inch of vacuum water gage will ensure that containment integrity is maintained at an acceptable level if all zones are connected to the SGTS at the same time.

The post-LOCA offsite dose analysis assumes a reactor enclosure secondary containment post-draw down leakage rate of 1250 cfm and certain post-accident X/Q values. While the post-accident X/Q values represent a statistical interpretation of historical meteorological data, the highest ground level wind speed which can be associated with these values is 7 mph (Pasquill-Gifford stability Class G for a ground level release). Therefore, the surveillance requirement assures that the reactor enclosure secondary containment is verified under meteorological conditions consistent with the assumptions utilized in the design basis analysis. Reactor Enclosure Secondary Containment leakage tests that are successfully performed at wind speeds in excess of 7 mph would also satisfy the leak rate surveillance requirements, since it shows compliance with more conservative test conditions.

THE Reactor Enclosure Secondary Containment Automatic Isolation Valves and Refueling Area Secondary Containment Automatic Isolation Valves can be found in the UFSAR.

ADD