

# New Hampshire Yankee

Ted C. Feigenbaum  
President and  
Chief Executive Officer

NYN- 92016

February 7, 1992

United States Nuclear Regulatory Commission  
Washington, D.C. 20555

Attention: Document Control Desk

References: Facility Operating License No. NPF-86, Docket No. 50-443


Subject: Annual Report of Primary Coolant Specific Activity

Gentlemen:

Seabrook Station Technical Specification 6.8.1.2.b requires that an annual report of primary coolant specific activity analyses which exceed the limits of Technical Specification 3.4.8, "Specific Activity", be submitted. In accordance with this requirement, New Hampshire Yankee hereby reports that during 1991 primary coolant specific activity did not exceed the limits of Technical Specification 3.4.8.

Should you have any questions regarding this report, please contact Mr. James M. Peschel, Regulatory Compliance Manager, (603) 474-9521, extension 3772.

Very truly yours,



Ted C. Feigenbaum

TCF:ALL/lad

9202250058 911231  
PDR ADDCK 05000443  
R FDR

240012

New Hampshire Yankee Division of Public Service Company of New Hampshire  
P.O. Box 300 • Seabrook, NH 03874 • Telephone (603) 474-9521

IE47  
40

United States Nuclear Regulatory Commission  
Attention: Document Control Desk

February 7, 1992  
Page two

cc: Mr. Thomas T. Martin  
Regional Administrator  
United States Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Gordon E. Edison, Sr. Project Manager  
Project Directorate I-3  
Division of Reactor Projects  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Mr. Noel Dudley  
NRC Senior Resident Inspector  
P.O. Box 1149  
Seabrook, NH 03874