

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

June 13, 1984

84 JUN 22 410:20

BLRD-50-438/81-05
BLRD-50-439/81-06

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30333

Dear Mr. O'Reilly:

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2 - LAMBDA POWER MODULE FAILURES -
BLRD-50-438/81-05, BLRD-50-439/81-06 - SUPPLEMENTAL REPORT


The subject deficiency was initially reported to NRC-OIE Inspector R. W. Wright on December 18, 1980 in accordance with 10 CFR 50.55(e) as NCR BLN EEB 8006. This was followed by our first interim report dated January 19, 1981; our final report dated July 21, 1981; our revised final report dated March 23, 1982; our second revised final report dated June 17, 1982; and our supplemental reports dated September 27, 1982; April 11 and September 12, 1983; and January 23, 1984.

As discussed with NRC-OIE Inspector R. Carroll on May 30, 1984, the date of June 1, 1984 for completion of corrective actions indicated in our final report on this matter would not be met. The affected power supplies are still in the possession of the vendor for replacement of suspect capacitors. The corrective action on this matter will be completed by December 12, 1984.

If you have any questions concerning this matter, please get in touch with R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

8406280300 840613
PDR ADOCK 05000438
S PDR

983-TVA 50TH ANNIVERSARY
An Equal Opportunity Employer

OFFICIAL COPY

IE 27

10