



Georgia Power

the southern electric system

D. O. Foster  
Vice President and Project  
General Manager  
Vogtle Project

JUN 14 11:02

June 4, 1984

United States Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303

File: X7BG03-M63  
Log: GN-370

Reference: Vogtle Electric Generating Plant-Units 1 and 2, 50-424, 50-425;  
Nuclear Service Cooling Water Supply and Return Piping

Attention: Mr. James P. O'Reilly


Gentlemen:

On May 3, 1984, Mr. R. E. Folker of Georgia Power Company notified Mr. John Rogge of the USNRC of a potentially reportable condition involving a suspected difference in the settlement of foundations of nuclear service cooling water tower and nearby valve houses. This suspected settlement difference may lead to an overstressed condition in the piping systems connecting the nuclear service cooling water towers.

At this time, the evaluation for the reportability of this subject is continuing. Based upon information and schedules supplied by our architect engineers, Georgia Power Company expects to submit a final report to the NRC on this subject by September 14, 1984.

This response contains no proprietary information and may be placed in the NRC Public Document Room upon receipt.

Yours truly,

  
D. O. Foster

REF/DOF/tm

xc: U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

R. J. Kelly  
R. E. Conway  
G. F. Head  
C. W. Hayes  
D. N. MacLemore

D. E. Dutton  
W. F. Sanders  
R. H. Pinson  
P. D. Rice  
R. A. Thomas

J. A. Bailey  
O. Batum  
G. Bockhold  
B. M. Guthrie  
E. D. Groover

L. T. Gucwa  
M. Malcom  
H. H. Gregory, III  
J. T. Beckham, Jr.  
J. L. Vota

Georgia Power Company  
Route 2, Box 299A  
Waynesboro, Georgia 30630  
Telephone 404 554-9961, Ext. 3360  
404 724-8114, Ext. 3360



PRP  
OFFICIAL COPY



Georgia Power

the southern electric system

D. O. Foster  
Vice President and Project  
General Manager  
Vogtle Project

7 All: 03

June 4, 1984

United States Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303

File: X7BG03-M63

Reference: Vogtle Electric Generating Plant-Units 1 and 2, 50-4/4 50-425;  
Nuclear Service Cooling Water Supply and Return Piping

Attention: Mr. James P. O'Reilly

Gentlemen:

On May 3, 1984, Mr. R. E. Folker of Georgia Power Company notified Mr. John Rogge of the USNRC of a potentially reportable condition involving a suspected difference in the settlement of foundations of nuclear service cooling water tower and nearby valve houses. This suspected settlement difference may lead to an overstressed condition in the piping systems connecting the nuclear service cooling water towers.

At this time, the evaluation for the reportability of this subject is continuing. Based upon information and schedules supplied by our architect engineers, Georgia Power Company expects to submit a final report to the NRC on this subject by September 14, 1984.

This response contains no proprietary information and may be placed in the NRC Public Document Room upon receipt.

Yours truly,

D. O. Foster

REF/DOF/tdm

xc: U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

R. J. Kelly  
R. E. Conway  
G. F. Head  
C. W. Hayes  
D. N. MacLemore

D. E. Dutton  
W. F. Sanders  
R. H. Pinson  
P. D. Rice  
R. A. Thomas

J. A. Bailey  
O. Batum  
G. Bockhold  
B. M. Guthrie  
E. D. Groover

L. T. Gucwa  
M. Malcom  
H. H. Gregory, III  
J. T. Beckham, Jr.  
J. L. Vota

OFFICIAL COPY  
1027/10