



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038

Nuclear Department

June 12, 1984

Dr. Thomas E. Murley, Administrator  
U. S. Nuclear Regulatory Commission  
Region 1  
631 Park Avenue  
King of Prussia, Pa. 19406

Dear Dr. Murley:


IE BULLETIN 83-07  
REVISED RESPONSE  
SALEM GENERATING STATION  
UNITS NO. 1 AND 2  
DOCKETS NOS 50-272 AND 50-311

By letter dated March 14, 1984, we provided a response to the subject bulletin. In that letter, we indicated that Salem Generating Station had not received any products sold by Ray Miller, Inc. In fact, we did receive some 304 and 304L stainless steel pipe and fittings from Richmond Engineering Co. (RECO) that had been furnished by Ray Miller, Inc. The Ray Miller pipe and fittings were used with Salem's CVCS Holdup tanks, Liquid Waste Monitors tanks and the Evaporator Bottoms tanks. Because the Ray Miller Inc. materials were not used in safety-related applications, they were mistakenly considered outside the scope of the bulletin, and thus, were not identified in our March 14, 1984 letter.

In our March 14, 1984 letter, we also committed to several actions to improve our ability to identify fraudulent vendor practices in the future. One short term commitment was to provide training to the Quality Assurance/Quality Control Receiving group. This training was to be completed by May 1, 1984; however, due to scope increases and late receipt of supporting information, it is still not complete. In order to provide valid training, several industry professional societies and organizations were contacted to obtain guidance on identifying fraudulent vendor practices. Such guidance information was not received within a time frame to support the May 1, 1984 date. Additionally, the scope of the potential problem is more critical than originally estimated,

thus additional development time was required. As of this date, the training program has been developed and is undergoing internal review and approval. Training for Quality Assurance/Quality Control Receiving group will be completed by June 22, 1984. Please note that this training will also be incorporated into our recurring training program for all Quality Assurance/Quality Control inspectors.

Sincerely,



E. A. Liden  
Manager - Nuclear  
Licensing and Regulation

C      Mr. Donald C. Fischer  
         Licensing Project Manager

         Mr. James Linville  
         Senior Resident Inspector

RECEIVED 6/13/84 11:30 AM  
U.S. NUCLEAR REGULATORY COMMISSION