

LICENSEE EVENT REPORT (LER)

| | | | | | | | | | | | | | | | | | |
|--|--------|--|----------------|---------------------|-----------------|------------------|-----------------|--------------|---------------------|---|--------|-----------|------------------|---|-------|------|--|
| FACILITY NAME (1) Dresden Nuclear Power Station Unit 2 | | | | | | | | | | DOCKET NUMBER (2) 0 5 0 0 0 2 1 3 7 | | | | PAGE (3) 1 OF 0 2 | | | |
| TITLE (4) East LPCI Corner Room Submarine Door Not Closed | | | | | | | | | | | | | | | | | |
| EVENT DATE (5) | | | LER NUMBER (6) | | | | REPORT DATE (7) | | | OTHER FACILITIES INVOLVED (8) | | | | | | | |
| MONTH | DAY | YEAR | YEAR | SEQUENTIAL NUMBER | REVISION NUMBER | MONTH | DAY | YEAR | FACILITY NAMES | | | | DOCKET NUMBER(S) | | | | |
| 0 | 2 | 0 | 8 | 8 | 4 | 0 | 0 | 6 | N/A | | | | 0 5 0 0 0 | | | | |
| 0 | 2 | 0 | 8 | 8 | 4 | 0 | 0 | 6 | 0 6 2 6 8 4 | | | | 0 5 0 0 0 | | | | |
| OPERATING MODE (9) | | THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11) | | | | | | | | | | | | | | | |
| N | | 20.402(b) | | | | 20.406(c) | | | | 50.73(a)(2)(iv) | | | | 73.71(b) | | | |
| POWER LEVEL (10) | | 20.406(a)(1)(i) | | | | 50.36(c)(1) | | | | 50.73(a)(2)(v) | | | | 73.71(c) | | | |
| 0 1 0 1 0 | | 20.406(a)(1)(ii) | | | | 50.36(c)(2) | | | | 50.73(a)(2)(vii) | | | | OTHER: (Specify in Abstract below and in Text, NRC Form 366A) | | | |
| | | 20.406(a)(1)(iii) | | | | 50.73(a)(2)(i) | | | | 50.73(a)(2)(viii)(A) | | | | | | | |
| | | 20.406(a)(1)(iv) | | | | 50.73(a)(2)(ii) | | | | 50.73(a)(2)(viii)(B) | | | | | | | |
| | | 20.406(a)(1)(v) | | | | 50.73(a)(2)(iii) | | | | 50.73(a)(2)(ix) | | | | | | | |
| LICENSEE CONTACT FOR THIS LER (12) | | | | | | | | | | | | | | | | | |
| NAME Mark Leahy | | | | | | | | | | TELEPHONE NUMBER (X-422) 8 1 5 9 4 2 - 2 9 2 1 0 | | | | | | | |
| COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13) | | | | | | | | | | | | | | | | | |
| CAUSE | SYSTEM | COMPONENT | MANUFACTURER | REPORTABLE TO NPROS | CAUSE | SYSTEM | COMPONENT | MANUFACTURER | REPORTABLE TO NPROS | CAUSE | SYSTEM | COMPONENT | MANUFACTURER | REPORTABLE TO NPROS | CAUSE | | |
| A | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |
| SUPPLEMENTAL REPORT EXPECTED (14) | | | | | | | | | | EXPECTED SUBMISSION DATE (15) | | MONTH | | DAY | | YEAR | |
| YES (If yes, complete EXPECTED SUBMISSION DATE) | | | | | | | | | | X NO | | | | | | | |

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

During normal operation, the east LPCI corner room submarine door to the torus basement was found open and unattended, in violation of the Technical Specifications. Safety significance was minimal since the operability of LPCI or Core Spray was not affected.

The door was probably left open by contractor personnel.

The door was immediately closed and secured, and signs were hung emphasizing the Technical Specification requirements.

This report is submitted as a result of an investigation which revealed that the event is reportable per 10 CFR 50.73 (a)(2)(i)(B). Originally the event was mistakenly classified as non-reportable.

Review of the circumstances which led to the misclassification indicate that station personnel involved were not completely familiar with the recent changes to 10 CFR 50.73. All personnel directly involved in determining reportability will receive additional training.

8407020269 840626
PDR ADOCK 05000237
S PDR

1/1 IE22

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104
EXPIRES: 8/31/85

| | | | | | | | |
|---|--|----------------|----------------------|--------------------|----------|----|----|
| FACILITY NAME (1) Dresden Station Unit 2 | DOCKET NUMBER (2) 0 5 0 0 0 2 3 7 8 4 | LER NUMBER (6) | | | PAGE (3) | | |
| | | YEAR | SEQUENTIAL NUMBER | REVISION NUMBER | | | |
| | | 84 | 006 | 01 | 02 | OF | 02 |

TEXT (If more space is required, use additional NRC Form 365A's) (17)

During normal operation, the east LPCI corner room submarine door to the torus basement was found open and unattended. Safety significance was minimal since the operability of the LPCI and Core Spray was not affected. Previous similar occurrence was reported by R.O. 83-81 on Docket #050-237.

Probable cause of the event was a contractor who was in the area prior to that time. The Station Construction Department has reminded the contractors of the requirement to keep the bulkhead door closed at all times. Also, additional signs have been hung on both sides of these doors, including the Unit 2 and 3 CCSW vaults, which state this requirement. The door in question was immediately closed and secured.

This report is submitted as a result of an investigation which revealed that the event is reportable per 10 CFR 50.73 (a)(2)(i)(B). Originally the event was mistakenly classified as non-reportable.

Review of the circumstances which led to the misclassification indicate that station personnel involved were not completely familiar with the recent changes to 10 CFR 50.73. All personnel directly involved in determining reportability will receive additional training.



Commonwealth Edison

Dresden Nuclear Power Station

R.R. #1

Morris, Illinois 60450

Telephone 815/942-2920

June 26, 1984

DJS Ltr #84-614

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Licensee Event Report #84-006-0, Docket #050237 is being submitted
as required by Technical Specification 6.6, NUREG 1022 and
10 CFR 50.73 (a)(2)(i)(B).

D.J. Scott
Station Superintendent
Dresden Nuclear Power Station

DJS/kjl

Enclosure

cc: J.G. Keppler, Regional Administrator, Region III
File/NRC
File/Numerical

IE22
11