



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640 JACKSON, MISSISSIPPI 39205

84 JUN 27

June 19, 1984

NUCLEAR LICENSING & SAFETY DEPARTMENT

U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30323

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File: 0260/L-835.0
Special Report 84-024/0 - Fire
Rated Penetrations Opened to
Implement Design Change Package
AECM-84/0314

On May 22, 1984, fire rated penetrations CE365G, CE379G, CE250D and CE208D were opened to implement a design change package. A fire watch was established in accordance with Technical Specification 3.7.7. until the penetrations were resealed. The Limiting Condition for Operation (LCO) will be restored upon the closure of paperwork.

This Special Report is submitted pursuant to Technical Specification 6.9.2 since the seven (7) day LCO time limit was exceeded. This condition had no effect on the health and safety of the public and did not constitute a threat to plant safety. This is a final report.

Yours truly,

L. F. Dale

L. F. Dale
Director of Nuclear Licensing & Safety

EBS/SHH:rg

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. N. S. Reynolds
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Member Middle South Utilities System

8407020286 840619
PDR ADOCK 05000416
S PDR

OFFICIAL COPY
1/0 LE 22