

Corrected

OPERATING DATA REPORT

DOCKET NO. 50-260
 DATE 4/1/84
 COMPLETED BY Ted Thom
 TELEPHONE 205/729-0834

OPERATING STATUS

1. Unit Name: Browns Ferry - 2
 2. Reporting Period: March 1984
 3. Licensed Thermal Power (MWt): 3293
 4. Nameplate Rating (Gross MWe): 1152
 5. Design Electrical Rating (Net MWe): 1065
 6. Maximum Dependable Capacity (Gross MWe): 1098.4
 7. Maximum Dependable Capacity (Net MWe): 1065
 8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A
 10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744	2,184	79,687
12. Number Of Hours Reactor Was Critical	744	1,893.84	51,858.02
13. Reactor Reserve Shutdown Hours	0	290.16	14,190.52
14. Hours Generator On-Line	744	1,849.14	50,341.98
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	1,574,676	5,034,528	145,179,573
17. Gross Electrical Energy Generated (MWH)	511,980	1,651,260	48,248,548
18. Net Electrical Energy Generated (MWH)	499,613	1,606,188	46,864,791
19. Unit Service Factor	100	84.7	63.2
20. Unit Availability Factor	100	84.7	63.2
21. Unit Capacity Factor (Using MDC Net)	63.1	69.1	55.2
22. Unit Capacity Factor (Using DER Net)	63.1	69.1	55.2
23. Unit Forced Outage Rate	0	11.2	24.4

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

July 1984 - Refuel

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

8407020383 840611
 PDR ADDCK 05000259
 R PDR

(9/77)