

Corrected

OPERATING DATA REPORT

DOCKET NO. 50-260
 DATE 5/1/84
 COMPLETED BY Ted Thom
 TELEPHONE 205/729-0834

OPERATING STATUS

1. Unit Name: Browns Ferry - Two
 2. Reporting Period: April 1984
 3. Licensed Thermal Power (MWt): 3293
 4. Nameplate Rating (Gross MWe): 1152
 5. Design Electrical Rating (Net MWe): 1065
 6. Maximum Dependable Capacity (Gross MWe): 1098.4
 7. Maximum Dependable Capacity (Net MWe): 1065
 8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

N/A

9. Power Level To Which Restricted, If Any (Net MWe) N/A
 10. Reasons For Restrictions, If Any: N/A

	This Month	Yr. to-Date	Cumulative
11. Hours In Reporting Period	<u>719</u>	<u>2,903</u>	<u>80,406</u>
12. Number Of Hours Reactor Was Critical	<u>719</u>	<u>2,612.84</u>	<u>52,577.02</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>290.16</u>	<u>14,190.52</u>
14. Hours Generator On-Line	<u>719</u>	<u>2,568.14</u>	<u>51,060.98</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>1,452,694</u>	<u>6,487,222</u>	<u>146,632,267</u>
17. Gross Electrical Energy Generated (MWH)	<u>461,900</u>	<u>2,113,160</u>	<u>48,710,448</u> *
18. Net Electrical Energy Generated (MWH)	<u>450,808</u>	<u>2,056,996</u>	<u>47,315,599</u>
19. Unit Service Factor	<u>100</u>	<u>88.5</u>	<u>63.5</u>
20. Unit Availability Factor	<u>100</u>	<u>88.5</u>	<u>63.5</u>
21. Unit Capacity Factor (Using MDC Net)	<u>58.9</u>	<u>66.5</u>	<u>55.3</u>
22. Unit Capacity Factor (Using DER Net)	<u>58.9</u>	<u>66.5</u>	<u>55.3</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>8.3</u>	<u>24.1</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each)			

August 1984 - Refuel

25. If Shut Down At End Of Report Period, Estimated Date of Startup
 26. Units In Test Status (Prior to Commercial Operation)

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

8407020385 840611
 PDR ADOCK 05000259
 R PDR

(9/77)