

TEXAS UTILITIES GENERATING COMPANY  
SKYWAY TOWER \* 400 NORTH OLIVE STREET, L.B. 81 \* DALLAS, TEXAS 75201

Log #TXX-4210  
File #10010  
#906.2

June 29, 1984

Director, Nuclear Reactor Regulation  
Attention:  
Mr. B.J. Youngblood  
Licensing Branch No. 1  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION  
DOCKET NOS. 50-445 and 50-446  
CONTAINMENT SUMP PERFORMANCE

REFERENCES: a. Meeting of June 7, 1984 - NRC & TUGCO (Containment Sump Performance)  
b. TUGCO Letter #TXX-4189 dated June 4, 1984 (Schmidt to Youngblood)

Dear Mr. Youngblood:

Attached is our consolidated report of the recently completed engineering analyses regarding Containment Sump Performance as the result of postulated debris accumulation following a loss of coolant accident.

As discussed in our meeting of June 7, 1984, these analyses clearly indicate that protective coatings inside containment need not be safety related as they have no safety significance. However, reaffirming the commitment made to you in our June 7 meeting, TUGCO will continue to apply these coatings using qualified materials, qualified applicators, and approved application procedures. In-process verification (inspection) of the coatings work will be accomplished by a craft group other than the applicators. Appropriate documentation will be maintained for surface preparation, primer, and finish coat application to satisfy the coatings specification. Additionally, the craft application and inspection activities will be monitored by Engineering to ensure the objective of an acceptable finished product with the desired corrosion protection and decontamination properties.

We plan to submit an amendment to our FSAP reflecting these changes no later than August, 1984. If you have questions, please call. Thank you for your prompt response.

Sincerely,

*H.C. Schmidt*

H.C. Schmidt

Manager, Nuclear Services

HCS:mapn  
attachment

8407030261 840629  
PDR ADOCK 05000443  
A PDR

VISION OF TEXAS UTILITIES ELECTRIC COMPANY

DIST REA S. BURMAN/

Boo! 1/4  
LTAS TO ALL  
EXCLS TO ALL  
NTIS  
C. Files  
FOR  
LPDR  
NSEC