

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

(215) 841-4502

June 27, 1984

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docket Nos.: 50-352
50-353

Subject: Limerick Generating Station, Units 1&2
Information for Containment Systems
Branch (CSB) Regarding SER Confirmatory
Issue No. 20 (Procedures for Hydrogen
Recombiner Operation)

Reference: Procedure No. S58.1.B, Revision 1:
Start-Up of a Containment Hydrogen
Recombiner from the Standby Condition
or Following a Trip

File: GOVT 1-1 (NRC)

Dear Mr. Schwencer:


We are pleased to offer the following information in
order to close out SER confirmatory issue #20.

Section 7.2 of the reference procedure provides the
following precaution to ensure that initiation of a
hydrogen recombiner will not create a steam bypass path
that could cause the containment design pressure to be
exceeded:

"Following an accident, do not place the hydrogen
recombiners in service until the reactor has been
depressurized."

Should any additional information be required, please
do not hesitate to contact us.

Sincerely,



JHA/gra/06188408

cc: See Attached Service List

8407060173 840627
PDR ADQCK 05000352
PDR

Boo!
1/0

cc: Judge Lawrence Brenner
Judge Richard F. Cole
Troy B. Conner, Jr., Esq.
Ann P. Hodgdon, Esq.
Mr. Frank R. Romano
Mr. Robert L. Anthony
Charles W. Elliot, Esq.
Zori G. Ferkin, Esq.
Mr. Thomas Gerusky
Director, Penna. Emergency
Management Agency
Angus R. Love, Esq.
David Wersan, Esq.
Robert J. Sugarman, Esq.
Spence W. Perry, Esq.
Jay M. Gutierrez, Esq.
Atomic Safety & Licensing
Appeal Board
Atomic Safety & Licensing
Board Panel
Docket & Service Section
Martha W. Bush, Esq.
Mr. James Wiggins
Mr. Timothy R. S. Campbell
Ms. Phyllis Zitzer
Judge Peter A. Morris