



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

July 5, 1984

NUCLEAR LICENSING & SAFETY DEPARTMENT

U.S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Washington, D.C. 20555

Attention: Mr. Harold R. Denton, Director

Dear Mr. Denton:

SUBJECT: Grand Gulf Nuclear Station  
Units 1 and 2  
Docket Nos. 50-416 and 50-417  
License No. NPF-13  
File 0260/L-860.0  
Division I D/G Disassembly,  
Reinspection, and Verification  
of Division II D/G As-  
Manufactured Similarity  
AECM-84/0345


Reference: Letter from Elinor G. Adensam to J. P. McGaughy, dated  
May 22, 1984

In accordance with the NRC Order of May 22, 1984 (Reference), Mississippi Power & Light Company (MP&L) has completed a disassembly and reinspection of the Unit 1 Division I standby diesel generator. The enclosed report details the reinspection program undertaken by MP&L.

The enclosed report also includes MP&L's comparison of the two Unit 1 standby diesel engines with regard to as-manufactured quality, maintenance history, inspection results, and operating history. MP&L's proposed, limited inspection activities for the Division II diesel engine are also discussed in the attached report.

As noted above, the required disassembly and reinspection of the Division I diesel engine has been completed. Following reassembly, the vendor recommended post-inspection testing was successfully completed. Currently the diesel generator is undergoing the preoperational testing required by the above referenced Commission Order, as clarified by the MP&L letter, AECM-84/0325, dated July 2, 1984. This preoperational testing is scheduled to be complete by July 7, 1984.

8407100267 840705  
PDR ADOCK 05000416  
G PDR

Acc'd  140

Add: J. Knight  
A. Ungaro  
C. Berlinger  
R. Caruso  
M. Miller

	Ltr	Encl
J. Knight	1	1
A. Ungaro	1	1
C. Berlinger	1	1
R. Caruso	1	1
M. Miller	1	1


G

etU1

Member Middle South Utilities System

This report, as requested, will be express mailed to your Staff's consultant, Pacific Northwest Laboratories. MP&L requests the opportunity to meet with your Staff and consultants, as soon as possible, to discuss the contents of this report and to resolve any questions they may have on this matter.

Yours truly,



L. F. Dale  
Director

WKH/GWS/JGC:lm  
Enclosure

cc: Mr. J. B. Richard (w/a)  
Mr. R. B. McGehee (w/a)  
Mr. N. S. Reynolds (w/a)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Mr. J. P. O'Reilly, Regional Administrator (w/a)  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30323

Ms. Elinor G. Adensam, Chief (w/a)  
Licensing Branch No. 4  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555