

LIMITING CONDITIONS FOR OPERATION

3.7. (cont'd.)

B. Standby Gas Treatment System

1. Except as specified in 3.7.B.3 below, both standby gas treatment systems shall be operable at all times when secondary containment integrity is required.
- 2.a. The results of the in-place cold DOP and halogenated hydrocarbon tests at design flows on HEPA filters and charcoal adsorber banks shall show >99% DOP removal and >99% halogenated hydrocarbon removal.
- b. The results of laboratory carbon sample analysis shall show >99% radioactive methyl iodide removal at a velocity within 20 percent of actual system design, ≥ 1.75 mg/m³ inlet methyl iodide concentration, >70% R.H. and $\leq 30^{\circ}\text{C}$.
- c. Fans shall be shown to operate within $\pm 10\%$ design flow.
3. From and after the date that one standby gas treatment system is made or found to be inoperable for any reason, reactor operation or fuel handling is permissible only during the succeeding seven days unless such system is sooner made operable, provided that during such seven days all active components of the other standby gas treatment system, and its associated diesel generator, shall be operable.

SURVEILLANCE REQUIREMENTS

4.7 (cont'd.)

B. Standby Gas Treatment System

1. At least once per operating cycle the following conditions shall be demonstrated.
 - a. Pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 6 inches of water at the system design flow rate.
 - b. Inlet heater input is capable of reducing R.H. from 100 to 70% R.H.
- 2.a. The tests and sample analysis of Specification 3.7.B.2 shall be performed at least once per year for standby service or after every 720 hours of system operation and following significant painting, fire or chemical release in any ventilation zone communicating with the system.
- b. Cold DOP testing shall be performed after each complete or partial replacement of the HEPA filter bank or after any structural maintenance on the system housing.
- c. Halogenated hydrocarbon testing shall be performed after each complete or partial replacement of the charcoal adsorber bank or after any structural maintenance on the system housing.
- d. Each system shall be operated with the heaters on at least 10 hours every month.
- e. Test sealing of gaskets for housing doors downstream of the HEPA filters and charcoal adsorbers shall be performed at, and in conformance with, each test performed for compliance with Specification 4.7.B.2.a and Specification 3.7.B.2.a.
3. System drains where present shall be inspected quarterly for adequate water level in loop-seals.

8407100473 840629
PDR ADOCK 05000298
P PDR

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.9.A

2. At least one diesel generator shall be operable during fuel handling operations. This one diesel shall be capable of supplying power to an operable Standby Gas Treatment System.

4.9.A.2 (cont'd)

During the monthly generator test the diesel generator starting air compressor shall be checked for operation and its ability to recharge air receivers. The operation of the diesel fuel oil transfer pumps and fuel oil day tank level switches shall be demonstrated, and the diesel starting time to reach rated voltage and frequency shall be logged.

- b. Once every 18 months the condition under which the diesel generator is required will be simulated and a test conducted to demonstrate that it will start and accept the emergency load within the specified time sequence. The results shall be logged.
 - c. Specification 4.9.A.2.c deleted.
 - d. Once a month the quantity of diesel fuel available shall be logged.
 - e. Every three months and upon delivery a sample of diesel fuel shall be checked for quality. The quality shall be within the acceptable limits specified in Table 1 of ASTM D975-68 for Nos. 1D or 2D and logged.
 - f. Each diesel generator shall be given an annual inspection in accordance with instructions based on the manufacturer's recommendations.
3. Unit Batteries
 - a. Every week the specific gravity, the voltage and temperature of the pilot

LIMITING CONDITIONS FOR OPERATION3.14 FIRE DETECTION SYSTEMAPPLICABILITY

Applies to the operational status of the Fire Detection System.

OBJECTIVE

To assure continuous automatic surveillance throughout the Main Plant.

SPECIFICATIONS

- A. The Fire Detection System instrumentation for each fire detection zone shown in Table 3.14 shall be operable.
- B. With one or more of the fire detection instrument(s) shown in Table 3.14 inoperable:
 - 1. Within 1 hour establish a fire watch patrol to inspect the zone(s) with the inoperable instrument(s) at least once per hour, and
 - 2. Restore the inoperable instrument(s) to OPERABLE status within 14 days or prepare and submit a Special Report to the Commission within the next 30 days outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the instrument(s) to OPERABLE status.

3.15 FIRE SUPPRESSION WATER SYSTEMAPPLICABILITY

Applies to the availability of water for fire fighting purposes.

OBJECTIVE

To assure a continuous operable water supply for fire fighting systems from 2 fire pumps.

SURVEILLANCE REQUIREMENTS4.14 FIRE DETECTION SYSTEMAPPLICABILITY

Applies to the operational status of the Fire Detection System.

SPECIFICATIONS

- A. Each detector on Table 3.14 shall be demonstrated operable every 6 months by performance of a channel functional test.
- B. The NFPA Code 72.D Class B supervised circuits supervision associated with the detector alarms of each of the above required fire detection instruments shall be demonstrated OPERABLE at least once per 6 months.

4.15 FIRE SUPPRESSION WATER SYSTEMAPPLICABILITY

Applies to the availability of water for fire fighting purposes.