

Commonwealth Edison Company  
LaSalle Generating Station  
2601 North 21st Road  
Marseilles, IL 61341-9757  
Tel 815/357-6761



**September 29, 1995**

**United States Nuclear Regulatory Commission  
Washington, D.C. 20555**

**Attention:** Document Control Desk

**Subject:** Closeout of Generic Letter 89-10 Activities

**Reference:** 1. D.L. Taylor (ComEd) letter to US NRC, dated September 28, 1990.  
2. L.O. DelGeorge (ComEd) letter to US NRC, dated November 1, 1993.

The Reference 1 and 2 letters transmitted LaSalle Station commitments to complete required actions associated with Generic Letter 89-10, "Safety-Related Motor-Operated Valve Testing and Surveillances". This letter notifies the NRC, per item m. of Generic Letter 89-10, that actions a. through h. are completed with exceptions noted below. This letter transmits LaSalle County Station's request for closure of Generic Letter 89-10.

There are 8 Motor Operated Valves (MOV's) on LaSalle Unit 1 that still require dynamic testing. The 8 MOV's, 4 globe valves and 4 flex wedge gate valves, are ranked in the Low and Low Low safety significant categories of LaSalle's deterministic/PRA prioritization for the Generic Letter 89-10 MOV population. A margin evaluation of the diagnostic data from completed static tests has shown more than adequate margin is available. The methodology used considered the significant uncertainties commonly used to predict MOV reliability. The remaining tests are scheduled during the next refuel outage which begins 01/26/96.

If there are any questions, please contact Baron Westphal at (815) 357-6761, ext. 2770.

Respectfully,

A handwritten signature in cursive script, appearing to read "R. E. Querio".

R. E. Querio  
Site Vice President  
LaSalle County Station

100033

9510110227 950929  
PDR ADDCK 05000373  
P PDR

A Unicom Company

A064  
1/0

cc: H. J. Miller, Regional Administrator, Region III  
W. D. Reckley, Project Manager, NRR  
P. G. Brochman, Senior Resident Inspector, LaSalle  
D. L. Farrar, Nuclear Regulatory Services Manager, NORS  
Central file