

# PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

OCT 04 1984

JOHN S. KEMPER  
VICE-PRESIDENT  
ENGINEERING AND RESEARCH

Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Docket Nos.: 50-352  
50-353

Subject: Limerick Generating Station, Units 1 and 2  
Pre-Operational Tests, Construction and  
Fire Protection Deferrals

References: 1) V. S. Boyer to A. Schwencer letter dated  
June 21, 1984.  
2) J. S. Kemper to A. Schwencer letter dated  
July 17, 1984.  
3) R. J. Stipceovich (PECO) and Byron Siegel (NRC)  
Conference Call dated 9/24/84.

File: GOVT 1-1 (NRC)

Dear Mr. Schwencer:

In reference letters no. 1 and 2 we requested certain pre-operational tests, construction and fire protection items be deferred until after fuel load in accordance with the technical justifications provided.

Since the time our request was made several of the items identified in our deferral request letters have been completed and consequently should be dropped from further consideration and not incorporated as license conditions in our low power license. The individual deferral items to be deleted were given to Mr. B. Siegel in the reference telephone call and are as follows:

|                       |   |  |
|-----------------------|---|--|
| Pre-operational Tests | - | 1P16.1 - Residual Heat Removal Service Water System.           |
|                       | - | 1P79.2B - Offgas Pretreatment and Radiation Monitoring.        |
|                       | - | 1P79.2C - Main Steam Line Radiation Monitoring.                |
| Construction          | - | Wrapping of Cables for Raceway Separation Criteria Compliance. |

8410100468 841004  
PDR ADDCK 05000352  
A PDR


B002  
110

Fire Protection

- Encapsulation of Raceway Required for Safe Shutdown.
- Heat Shield and Spill Protection - Load Centers at EL 313 Reactor Building.
- Repair to Existing Structural Steel Coating.
- Internal Seals for Conduits That Penetrate Fire Barriers.

All other deferral items in reference letters no. 1 and 2 remain unchanged. Should you require additional information or clarification, we would be pleased to discuss this in greater detail.

Sincerely,



RJS/gra/10018402

cc: See Attached Service List

cc: Judge Helen F. Hoyt  
Judge Jerry Harbour  
Judge Richard F. Cole  
Judge Christine N. Kohl  
Judge Gary J. Edles  
Judge Reginald L. Gotchy  
Troy B. Conner, Jr., Esq.  
Ann P. Hodgdon, Esq.  
Mr. Frank R. Romano  
Mr. Robert L. Anthony  
Ms. Phyllis Zitzer  
Charles W. Elliot, Esq.  
Zori G. Ferkin, Esq.  
Mr. Thomas Gerusky  
Director, Penna. Emergency Management Agency  
Angus R. Love, Esq.  
David Wersan, Esq.  
Robert J. Sugarman, Esq.  
Martha W. Bush, Esq.  
Spence W. Perry, Esq.  
Jay M. Gutierrez, Esq.  
Atomic Safety & Licensing Appeal Board  
Atomic Safety & Licensing Board Panel  
Docket & Service Section  
Mr. James Wiggins  
Mr. Timothy R. S. Campbell