

1/13/84 50-280
F

VIRGINIA ELECTRIC AND POWER COMPANY
SURREY POWER STATION
EMERGENCY PLAN IMPLEMENTING PROCEDURE

NUMBER	PROCEDURE TITLE	REVISION
EPIP-1.01	'84 APR -4 A9 EMERGENCY MANAGER CONTROLLING PROCEDURE (With 1 Attachment)	09
		PAGE
		1 of 8

PURPOSE

To initially assess a potential emergency condition and initiate corrective actions.

USER

Shift Supervisor or Station Emergency Manager

ENTRY CONDITIONS

Any one of the following :

1. Another station procedure directs initiation of this procedure

OR

2. A potential emergency condition is reported to the Shift Supervisor.

REVISION RECORD

REV. 04	PAGE(S): 1 of 8 and Att. 1 Page 19 and 20 of 39	DATE:03-03-83
REV. 05	PAGE(S): 1 of 8, Att. 1 page 4, 22, and 23 of 39	DATE:03-10-83
REV. 06	PAGE(S): 1 of 8 and 4 of 8	DATE:03-11-83
REV. 07	PAGE(S): 1 Of 8, Att. 1 page 13 of 39	DATE:03-17-83
REV. 08	PAGE(S): 1, 5, 6 & 8; Att. 1, pgs. 2 through 13, 15, 17, 18, 20, and 23 through 38	DATE:11-10-83
REV. 09	PAGE(S): 1 of 8 and 5 of 8	DATE: JAN 13 1984

APPROVAL RECOMMENDED

QC REVIEW

APPROVED

DATE

JAN 13 1984

CHAIRMAN STATION NUCLEAR SAFETY
AND OPERATING COMMITTEE

8403280125 840113
PDR ADOCK 05000280
PDR

NUMBER	PROCEDURE TITLE	REVISION
EPIP-1.01	EMERGENCY MANAGER CONTROLLING PROCEDURE	09
		PAGE 5 of 8

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
4.	(CONTINUED)	
	2) SRO-On-Call	
	R. Johnson	Attempt contact via beeper
	OR	
	J. Agler	Attempt contact via beeper
	c) Verify classification	
	d) IF required by Alert, Site Area Emergency or General Emergency, request initiation of Standing Order 21	
	NOTE: Return to Step 2 of this instruction as necessary during the course of the situation for additional events and reclassification.	
5.	VERIFY EALS EXCEEDED:	
	a) Assure EALS - EXCEEDED	a) IF EALS NOT exceeded, DO NOT declare an emergency classification.
		AND
		1) Continue appropriate corrective action IAW procedures.
		2) GO TO Step 7 of this procedure.

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

January 23, 1984

Mr. James F. O'Reilly
Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 2900
Atlanta, Georgia 30303

Serial No. 043
NO/REB/jmj:LM1-031
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Dear Mr. O'Reilly:

REVISIONS TO
SURRY POWER STATION
EMERGENCY PLAN IMPLEMENTING PROCEDURES

Pursuant to 10CFR 50, Appendix E, paragraph 50.54(q), revisions to the Surry Power Station Emergency Plan Implementing Procedures, numbers, and subjects as listed on enclosures are submitted.

Sincerely,

W. L. Stewart

Enclosures

cc: Document Control Desk (2)

w/o Enclosures

cc: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1

Mr. D. J. Burke - (NRC - Surry)

x005
1/11

VIRGINIA ELECTRIC AND POWER COMPANY

REVISIONS TO
SURRY POWER STATION
EMERGENCY PLAN IMPLEMENTING PROCEDURES

Enclosed are recently revised pages to the Surry Power Station Emergency Plan Implementing Procedures. Please take the following actions in order to keep your manual updated with the most recent revisions.

EPIP-1.01

EMERGENCY MANAGER CONTROLLING PROCEDURE

Remove and Destroy

Pages 1 of 8 and
page 5 of 8, Rev. 08

Enter

Page 1 of 8 and
page 5 of 8, Rev. 09.
Dated 01-13-84





UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 22, 1984

50-280/281 Surry

MEMORANDUM FOR: Chief, Document Management Branch, TIDC
FROM: Director, Division of Rules and Records, ADM
SUBJECT: REVIEW OF UTILITY EMERGENCY PLAN DOCUMENTATION

The submitter of the attached document has expressed no desire to withhold any information contained therein. Therefore, this material may now be made publicly available.


J. M. Felton, Director
Division of Rules and Records
Office of Administration 

Attachment: As stated