



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

September 27, 1984

FILE: BG9-13510C
SERIAL: BSEP/84-2050

NRC Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT UNIT 1
DOCKET NO. 50-325
LICENSE NO. DPR-71
LICENSEE EVENT REPORT 1-84-19

Gentlemen:

On September 1, 1984, performance of the channel functional test of the Unit 1 Reactor Building Ventilation Monitoring System, PT-04.2.3, revealed that an appropriate Control Room alarm annunciator did not function. The Licensee Event Report of this event, identified as LER 1-84-19, was to be submitted to your office by October 1, 1984; however, the investigation concerning this event is not yet complete. LER 1-84-19 will be submitted by November 1, 1984.

Very truly yours,

C. R. Dietz, General Manager
Brunswick Steam Electric Plant

MJP/sdl/LETSDL

cc: Mr. J. P. O'Reilly

8410100771 840927
PDR ADOCK 05000325
S PDR

IE22
1/0