



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

dmB

June 19, 1984

Mr. James G. Keppler
Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Mr. Keppler:

In accordance with LaSalle County Station Unit 1 Facility Operating License NPF-11, Appendix B, Section 3.2, we are submitting to you a copy of the NPDES noncompliance for LaSalle County Nuclear Generating Station Permit No. IL0048151.

G. J. Diederich
Station Superintendent

GJD/FRL/SKD/kg

Enclosure

xc: DVR Report

JUN 29 1984

B407160170 B40619
PDR ADOCK 05000373
S PDR

11
IEO1



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

June 4, 1984

U.S. Environmental Protection Agency
Region V, Enforcement Division
ATTN: Chief, Compliance Unit
230 South Dearborn Street
Chicago, IL 60604


Illinois Environmental Protection Agency
Division of Water Pollution Control
Compliance Management Unit
2200 Churchill Road
Springfield, IL 62706

Dear Sir:

Subject: NPDES Noncompliances for LaSalle County Nuclear
Generating Station - Permit No. IL0048151

In accordance with Standard Condition 12, we wish to submit the following notice of a noncompliance which is listed on the attached table.

If there are any questions, please contact Steve Davis of my staff at (815) 357-6761, extension 487.


G. J. Diederich
Station Superintendent

GJD/FRL/SKD/bej

xc: Director of Water Quality, Environmental Affairs
Manager, Nuclear Stations Division

LASALLE COUNTY NUCLEAR GENERATING STATION
N.P.D.E.S. PERMIT NO: IL0048151
NONCOMPLIANCE REPORT

DISCHARGE NUMBER AND DESCRIPTION: 001c Wastewater Treatment Facility Effluent

PARAMETER AND PERMIT LIMIT: pH, 6.0 - 9.0 S.U.

NONCOMPLIANCE, DATE, AND DURATION: 9.8 S.U., 30MAY84, unknown (believed
to be less than 8 hours)

CAUSE OF NONCOMPLIANCE: The MUD clean sump was sampled and analyzed for pH
on 30MAY84. The 11.2 S.U. result indicated the sump was the source of the
high pH water. The original source is unknown.

CORRECTIVE ACTION: The discharge was stopped. The clearwell was circulated
back to the equalization tank and neutralized. Resamples were drawn at 1630
on 01JUN84. The results indicated the clearwell pH was 9.0 S.U. and the
equalization tank was 7.6 S.U. Wastewater Treatment Facility operations
were then returned to normal.

DATE RECOGNIZED AS A VIOLATION:

30MAY84

DATE INVESTIGATED:

30MAY84