

 **Nuclear**

GPU Nuclear Corporation
Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

July 10, 1984

Mr. John Gaston, Director
Division of Water Resources
Department of Environmental Protection
P.O. Box CN-029
Trenton, NJ 08625


Dear Mr. Gaston:

Subject: GPU Nuclear Corporation
Oyster Creek Nuclear Generating Station
NJPDES Permit No. NJ 000 5550

Enclosed is the Discharge Monitoring Report for the subject permit for the month of June 1984. Please note that there were no noncompliances with any maximum or minimum effluent limitations during this reporting period.

If you have any further questions concerning this report, please contact Mr. Douglas Moore of our Licensing and Regulatory Affairs Department at (609) 971-4630.

Very truly yours,



Peter B. Fiedler
Vice President & Director
Oyster Creek

PBF:DFM:dsm
Enclosures

(cc: Page 2)

8407160200 840710
PDR ADOCK 05000219
R PDR

IE25
1/1

To: John Gaston, Director
Dept. of Environmental Protection
Re: Discharge Monitoring Report
Page 2

cc: U.S. Environmental Protection Agency
Room 432
26 Federal Plaza
New York, NY 10278
Attn: Permits Administration Branch
Marion Burger

U.S. Army Corps of Engineers
Custom House
Second & Chestnut Streets
Philadelphia, PA 19106

Dr. Thomas E. Murley, Administrator
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Director
Office of Nuclear Reactor Regulations
U.S. Nuclear Regulatory Commission
Washington, DC 20555
c/o Distribution Services Branch, DDC, ADM

NJPDES PERMIT 000 5550

GPU Nuclear Corporation

Comments for Oyster Creek - June 1984

1. The Oyster Creek Nuclear Generating Station did not operate during the month of June 1984 as a result of the maintenance/refueling outage currently in progress.
2. Circulating water pumps 1-1, 1-2, 1-3, and 1-4 were not operated in June.
3. Dilution pump 1-1 was operated on June 13 through 17, and 24, 1984.
Dilution pump 1-2 was operated on June 2, 7, 26, 27, 29, and 30, 1984.
Dilution pump 1-3 was operated on June 1, 2, 7, 13 through 17, 24, 29, and 30, 1984.
4. The main condensers were not chlorinated during June.
5. The value reported for total suspended solids, discharge DMW is the average value of the analysis of two aliquots of the same sample.
6. There was no disposal of plant screenings during the second quarter, 1984.