

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

JUL 10 1984

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

Mr. Thomas E. Murley, Director
United States Nuclear Regulatory Commission
Office of Inspection and Enforcement, Region I
631 Park Avenue
King of Prussia, PA 19406

SUBJECT: NRC Region I Letter dated March 12, 1984
RE: IE Bulletin No. 84-02
Failures of General Electric Type HFA Relays
in Use in Class 1E Safety Systems
Limerick Generating Station Units 1 and 2
Docket Nos. 50-352 and 50-353

FILE: Govt 1-1 (IE Bulletins)

Dear Mr. Murley:

The Philadelphia Electric Company has reviewed IE Bulletin No. 84-02 submitted with the subject letter, received on March 12, 1984.

General Electric type HFA relays are supplied in the safety and non safety-related systems in both units at the Limerick Generating Station. Twelve (12) relays per unit are provided in the safety-related systems, and approximately 120 relays per unit are supplied in the non safety-related systems.

The following program was determined in order to address the HFA relay concerns at Limerick:

- I. The GE type HFA relays in use in Class 1E systems will be replaced with the new Century Series type HFA relays. This action is in compliance with the manufacturer's recommendation presented in Service Advice No. 721-PSM-152.2A, dated 6/7/82.
- II. The coil assemblies of the GE type HFA relays in the non-Class 1E systems will be replaced with the new Century Series relay coil conversion kits.


8407170084 840710
PDR ADOCK 05000352
PDR
G

At present, this corrective action, HFA relay/coil assembly replacement, is 90% complete for Unit 1. All HFA relays in the safety-related systems have been replaced, but several coil conversions are still required. It is expected that the Unit 1 replacement will be completed by September 15, 1984. No HFA relays/coil assemblies have been replaced in Unit 2 at this time.

In order to prevent their use as replacement parts in future maintenance efforts at Limerick, the older and problematic HFA relays/coil assemblies will be discarded.

In addition, an adequate number of new coil conversion kits have been supplied for the replacement of existing coils in presently "spare" HFA relays in the non-Class 1E systems at Limerick. Century Series type HFA relays will be purchased as "spares" for HFA relays in the safety-related applications at Limerick.

Sincerely,



MHH:nel-p

nel-p07028411245

Copy to: Director of Inspection and Enforcement
United States Nuclear Regulatory Commission
Washington, DC 20555

S. K. Chaudhary, Resident NRC Inspector (Limerick)
J. Wiggins, Resident NRC Inspector (Limerick)

COMMONWEALTH OF PENNSYLVANIA :

SS.

COUNTY OF PHILADELPHIA :

JOHN S. KEMPER, being first duly sworn, deposes
and says:

That he is Vice President of Philadelphia
Electric Company, the holder of Construction Permits
CPPR-106 and CPPR-107 for Limerick Generating Station
Units 1 and 2; that he has read the foregoing Response
to IE Bulletin 84-02 for Docket No. 50-352 and 50-353
and knows the contents thereof; and that the statements
and matters set forth therein are true and correct to
the best of his knowledge, information and belief.

John S. Kemper

Subscribed and sworn to
before me this 10th day
of July, 1984.

Patricia D. Scholl

PATRICIA D. SCHOLL
Notary Public, Philadelphia, Philadelphia Co.
My Commission Expires February 10, 1986