


VERMONT YANKEE NUCLEAR POWER CORPORATION



RD 5, Box 169, Ferry Road, Brattleboro, VT 05301

June 21, 1984

FVY 84-69

REPLY TO:

ENGINEERING OFFICE

1671 WORCESTER ROAD
FRAMINGHAM, MASSACHUSETTS 01701
TELEPHONE 617-872-8100

United States Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Office of Nuclear Reactor Regulation
Mr. Domenic B. Vassallo, Chief
Operating Reactors Branch No. 2
Division of Licensing

References: (a) License No. DPR-28 (Docket No. 50-271)
(b) Letter, VYNPC to USNRC, FVY 84-46, dated May 15, 1984

Subject: Degraded Grid Voltage Protection

Dear Sir:

By letter dated May 15, 1984 [Reference (b)], we provided you with additional information regarding our proposed scheme for degraded grid voltage protection at our facility. Subsequent to our submittal, we have held conference calls with members of your staff to clarify certain details of this scheme. The purpose of this letter is to provide you with the following information which supersedes our response to Item (1) of Reference (b).

Loss of normal ac power, or low emergency bus voltage sensed on an emergency bus for ten seconds in conjunction with an accident signal, will cause the following sequence of events:

- a. The associated diesel generator will start,
- b. The bus tie breaker between the emergency bus and the off-site power source will open, and
- c. The emergency bus will shed loads.

Once the diesel generators are at their required operating voltage, the diesel generator breakers close, and the emergency bus loads are sequenced onto the bus. While the diesel generators are supplying the emergency buses, load shedding is blocked by relay logic. The scheme includes an additional relay which automatically reinstates load shedding, should either diesel generator breaker trip.

We trust that the above information is deemed acceptable; however, should you have any questions regarding this matter, please contact us.

Very truly yours,

VERMONT YANKEE NUCLEAR POWER CORPORATION

J.B. Sinclair
J. B. Sinclair
Licensing Engineer

B407170253 B40621
PDR ADOCK 05000271
P PDR

JBS/kg

A015
1/0