



GPU Nuclear Corporation
Route 441 South
P.O. Box 480
Middletown, Pennsylvania 17057-0480
(717) 944-7621
Writer's Direct Dial Number:
(717) 948-8005

October 9, 1995
C311-95-2412

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Dear Sir:

Subject: Three Mile Island Nuclear Station, Unit I (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Once Through Steam Generator (OTSG) Tubes - Post Inservice
Inspection (ISI) Report for Cycle 11 Refueling (11R) Outage

This letter fulfills the TMI-1 Technical Specification 4.19.5.a requirement that GPU Nuclear submit a report to the NRC of the number of tubes repaired or removed from service in each OTSG within 15 days of the completion of each ISI of the OTSG tubes.

During the 11R Outage, our evaluation of the OTSG eddy current inspection results determined the need to remove six defective tubes from service by plugging. Specifically, one sleeved tube was plugged in OTSG "A" and five tubes were plugged in OTSG "B." The installation of these plugs was completed on September 30, 1995.

A total of 1269 tubes have been removed from service in OTSG "A" and 378 in OTSG "B" since their fabrication.

Sincerely,

J. Knubel
Vice President and Director, TMI

160099

MRK

9510170103 951009
PDR ADDCK 05000289
Q PDR

cc: Administrator, NRC Region I
TMI Senior NRC Resident Inspector
TMI Senior NRC Project Manager

A047
1/0