

OPERATING DATA REPORT

DOCKET NO: 50-368
 DATE: August 1984
 COMPLETED BY: L.S. Bramlett
 TELEPHONE: 501-964-3145

OPERATING STATUS

1. Unit Name: Arkansas Nuclear One - Unit 2
2. Reporting Period: August 1-31, 1984
3. Licensed Thermal Power (MWt): 2815
4. Nameplate Rating (Gross MWe): 942.57
5. Design Electrical Rating (Net MWe): 912
6. Maximum Dependable Capacity (Gross MWe): 897
7. Maximum Dependable Capacity (Net MWe): 858
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
9. Power Level To Which Restricted. If Any (Net MWe): None
10. Reasons For Restrictions. If Any: None

	MONTH	YR-TO-DATE	CUMULATIVE
11. Hours in Reporting Period	744.0	5,855.0	38,879.0
12. Number of Hours Reactor was Critical	656.6	4,876.9	26,504.0
13. Reactor Reserve Shutdown Hours	0.0	0.0	1,430.1
14. Hours Generator On-Line	656.6	4,715.2	25,665.5
15. Unit Reserve Shutdown Hours ..	0.0	0.0	75.0
16. Gross Thermal Energy Generated (MWH)	1,803,614.0	12,123,740.0	64,673,280.0
17. Gross Electrical Energy Generated (MWH)	599,561.0	4,035,313.0	21,052,264.0
18. Net Electrical Energy Generated (MWH)	573,046.0	3,847,635.0	20,055,975.0
19. Unit Service Factor	88.3	80.5	66.0
20. Unit Availability Factor	88.3	80.5	66.2
21. Unit Capacity Factor (Using MDC Net)	89.8	76.6	60.1
22. Unit Capacity Factor (Using DER Net)	84.5	72.1	56.6
23. Unit Forced Outage Rate	11.7	7.6	18.3
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):	None		
25. If Shut Down At End of Report Period. Estimated Date of Startup:	September 3, 1984 (Down 8/29 - 9/3 repair leaks)		
26. Units in Test Status (Prior to Commercial Operation):			

Forecast Achieved

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-368
 UNIT: Two
 DATE: 9/10/84
 COMPLETED BY: L.S. Bramlett
 TELEPHONE: 501-964-3145

MONTH August, 1984

DAY AVERAGE DAILY POWER LEVEL
 (MWe-Net)

1	716
2	716
3	734
4	862
5	890
6	889
7	889
8	891
9	892
10	891
11	894
12	892
13	892
14	894
15	893
16	893
17	892
18	889
19	890
20	892
21	890
22	889
23	894
24	898
25	898
26	896
27	893
28	323
29	0
30	0
31	0

INSTRUCTION

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

NRC MONTHLY OPERATING REPORT

OPERATING SUMMARY

AUGUST 1984

UNIT 2

The unit started the month at 80% power holding for ASI and NI calibration. The unit was taken to 93% power on August 3rd and then to 100% full power on August 4th.

At 0839 hours on August 28th the unit tripped because of a dropped CEA. The unit went to cold shutdown for repair of RCP seal leak and a steam generator manway leak. The unit remained in cold shutdown through the end of the month.

UNIT SHUTDOWNS AND POWER REDUCTIONS
REPORT FOR AUGUST, 1984

DOCKET NO	50-368
UNIT NAME	AND-2
DATE	9/4/84
COMPLETED BY	L.S. Bramlett
TELEPHONE	501-964-3145

<u>No.</u>	<u>Date</u>	<u>Type</u> ¹	<u>Duration</u> (Hours)	<u>Reason</u> ²	<u>Method of</u> <u>Shutting</u> <u>Down Reactor</u> ³	<u>Licensee</u> <u>Event</u> <u>Report #</u>	<u>System</u> <u>Code</u> ⁴	<u>Component</u> <u>Code</u> ⁵	<u>Cause & Corrective</u> <u>Action to</u> <u>Prevent Recurrence</u>
8408	840828	F	87.35	A	3	2-84248	ZZ	ZZZZZZ	The unit tripped due to a dropped CEA. The unit then went to CSD to repair a faulty RCP seal and a leaking steam generator manway.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training &
License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Continuation
5-Load Reduction
9-Other

4
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

5
Exhibit 1 - Same Source

DATE: August 1984

REFUELING INFORMATION

1. Name of facility: Arkansas Nuclear One - Unit 2
2. Scheduled date for next refueling shutdown. May 1985
3. Scheduled date for restart following refueling. July 1985
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? If answer is yes, what, in general, will there be? If answer is no, has the reload fuel design and core configuration been reviewed by your Plant Safety Review Committee to determine whether any unreviewed safety questions are associated with the core reload (Ref. 10 CFR Section 50.59)?

Yes, some software changes to the Core Protection Calculators will be made.
5. Scheduled date(s) for submitting proposed licensing action and supporting information. February 1985
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.

Burnable poison rods will be used in reload fuel.
7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool. a) 177 b) 168
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.

present 988 increase size by 0
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity.

DATE: 2003



ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

September 15, 1984

2CAN098409

Mr. Harold S. Bassett, Director
Division of Data Automation
and Management Information
Office of Resource Management
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

SUBJECT: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
Monthly Operating Report
(File: 2-0520.1)

Gentlemen:

Attached is the NRC Monthly Operating Report for August 1984 for Arkansas Nuclear One - Unit 2.

Very truly yours,

John R. Marshall
Manager, Licensing

JRM:SAB:ac

Attachment

cc: Mr. John T. Collins
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Mr. Richard C. DeYoung
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, DC 20555

IE24
1/1