



J. Philip Bayne  
Executive Vice President  
Nuclear Generation

July 16, 1984  
JPN-84-45

Director of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Attention: Mr. Domenic B. Vassallo, Chief  
Operating Reactors Branch No. 2  
Division of Licensing

Subject: James A. FitzPatrick Nuclear Power Plant  
Docket No. 50-333  
NUREG-0737 Item II.B.3  
Post Accident Sampling System (PASS)

Reference: 1. NYPA letter, J. P. Bayne to D. B. Vassallo,  
dated April 16, 1984 (JPN-84-23).

Dear Sir:

The purpose of this letter is to confirm information provided to the NRC staff by Authority personnel in a recent telephone conversation.

Reference 1 stated that training for applicable personnel in the collection, transport, and on-site analysis of samples from the PASS would be conducted annually.

Although each individual will be trained annually, the Authority will hold training sessions semi-annually, so that approximately one-half of the affected personnel will be trained every six months. This will ensure that at any given time there are personnel available who have received training within the past six months. It should also be noted that the


8407230009 840716  
PDR ADOCK 05000333  
P PDR

A046  
1/10

FitzPatrick Emergency Plan currently requires that a sample be taken at least once every six months.

If you have any questions, please contact Mr. J. A. Gray, Jr. of my staff.

Very truly yours,



J. P. Bayne  
Executive Vice President  
Nuclear Generation

cc: Office of the Resident Inspector  
U. S. Nuclear Regulatory Commission  
Post Office Box 136  
Lycoming, New York 13093