




KANSAS GAS AND ELECTRIC COMPANY

July 11, 1984

GLENN L KOESTER
VICE PRESIDENT - NUCLEAR

Mr. E. H. Johnson, Acting Chief
Reactor Projects Branch 2
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



KMLNRC 84-114

Re: Docket No. STN 50-482

Subj: Withdrawal of Potential 10CFR50.55(e)
Containment Spray Pump Venting

Dear Mr. Johnson:

This letter withdraws the potential 10CFR50.55(e) concerning venting of the containment spray pumps at Wolf Creek Generating Station. This matter was initially reported by Mr. H. K. Chernoff of Kansas Gas and Electric Company (KG&E) to Mr. Doyle Hunnicutt of the Nuclear Regulatory Commission, Region IV, on June 14, 1984.

The Architect/Engineer has completed an engineering evaluation of the "as-built" configuration on the containment spray pump seal piping and determined that the pump seal piping can be adequately vented. Based on the results of this evaluation, KG&E has determined that the existing conditions would not have affected adversely the safety of operations of Wolf Creek Generating Station had they gone uncorrected. Therefore, KG&E has concluded that this matter is not reportable pursuant to 10CFR50.55(e).

Please contact me or Mr. Otto Maynard of my staff if you have any questions concerning this subject.

Yours very truly,

Glenn L Koester

GLK:dsn

xc: RCDeYoung
PO'Connor
HBundy

8407230330 840711
PDR ADOCK 05000482
S PDR

11-27
1/0