

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004
Expires 2-29-84

NAME DUQUESNE LIGHT COMPANY
ADDRESS BEAVER VALLEY ATOMIC POWER ST.
2841 NEW BEAVER AVENUE
PITTSBURGH PA 15233
FACILITY _____
LOCATION _____

PA0025615

PERMIT NUMBER

401 A

DISCHARGE NUMBER

I - INITIAL LIMITS
401 A COOLING TOWER PUMPHOUSE

IDS
11

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	84	08	01		84	08	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
PH	SAMPLE MEASUREMENT	*****	*****	*****		*****				
00400 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU	ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	*****	*****					
00530 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*****	*****	30 DAILY AV	100 DAILY MX	MG/L	ONCE/ MONTH	GRAB
OIL AND GREASE FREDN EXTR-GRAV METH	SAMPLE MEASUREMENT	*****	*****	*****	*****					
00556 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*****	*****	15 DAILY AV	20 DAILY MX	MG/L	ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT				*****	*****	*****	*****		
50050 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****	ONCE/ MONTH	ESTIMA
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

C. Feitknecht
General Manager
Fossil Generation Unit

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 73 USC § 1319 (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

412 393-4343
AREA CODE NUMBER

YEAR MO DAY

SAMPLES TAKEN AT LOC 01 COOL TOWER PUMPHOUSE LOW VOLUME, PRIOR TO COMB WITH OTHER EFFLUENT.
SEE P 23 AND 24, SPECIAL CONDITIONS.

8410150514 840831
PDR ADDCK 05000334
R PDR

PERMITTEE NAME/ADDRESS (Include
Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004
Expires 2-29-84

NAME **DUQUESNE LIGHT COMPANY**
ADDRESS **BEAVER VALLEY ATOMIC POWER ST.**
2841 NEW BEAVER AVENUE
PITTSBURGH PA 15233
FACILITY _____
LOCATION _____

PA0025615

PERMIT NUMBER

004 A

DISCHARGE NUMBER

F - FINAL LIMITS
004 A COOLING TOWER OVERFLOW

MONITORING PERIOD

YEAR	MO	DAY	TO	YEAR	MO	DAY
84	08	01		84	08	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

ATTN: C. FEITKNECHT, GEN. SUPT

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
PH	SAMPLE MEASUREMENT	*****	*****	*****	7.83	*****	7.83	0	Once Month	Grab
00400 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	SU	ONCE/ MONTH	GRAB
FLOW, IN CONDUIT DR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	<0.001	<0.001		*****	*****	*****		Once Month	Estima
50050 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****		ONCE/ MONTH	ESTIMA
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

C. Feitknecht
General Manager
Fossil Generation Unit

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED
AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED
ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR
OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION
IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIG-
NIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING
THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND
33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000
and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

412 393-4343
AREA CODE NUMBER

YEAR MO DAY

NEW MONITORED ONCE PER MONTH ONLY WHEN DISCHARGING.

SEE P 23 AND 24, SPECIAL CONDITIONS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **DUQUESNE LIGHT COMPANY**
 ADDRESS **BEAVER VALLEY ATOMIC POWER ST.**
2841 NEW BEAVER AVENUE
PITTSBURGH PA 15233

FACILITY
 LOCATION

ATTN: C. FEITKNECHT, GEN. SUPT

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

PA0025615

PERMIT NUMBER

303 A

DISCHARGE NUMBER

I - INITIAL LIMITS

303 A NONRAD SYSTEM LEAKAGE

Form Approved
 OMB No. 2040-0004
 Expires 2-29-84

MONITORING			TO	PERIOD		
YEAR	MO	DAY		YEAR	MO	DAY
84	08	01		84	08	31
(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			(5 Card Only) QUALITY OR CONCENTRATION (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM		
PH	SAMPLE MEASUREMENT	*****	*****	*****	7.46	*****	7.46					Once/ Month	Grab
00400 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU				ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	*****	*****	87	87					Once/ Month	Grab
00530 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*****	*****	30 30DA AV	100 7DA AV	MG/L				ONCE/ MONTH	GRAB
OIL AND GREASE FREON EXTR-GRAV METH	SAMPLE MEASUREMENT	*****	*****	*****	*****	9	9					Once/ Month	Grab
00556 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*****	*****	15 30DA AV	20 7DA AV	MG/L				ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.015	0.034		*****	*****	*****	*****				Once/ Month	Estima
50050 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****				ONCE/ MONTH	ESTIMA
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

C. Feitknecht
 General Manager
 Fossil Generation Unit

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

412 393-4343

AREA CODE

NUMBER

DATE

YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 SAMPLES TAKEN AT NONRAD SYSTEM & FLOOR DRAIN SYSTEM PRIOR TO COMBINATION WITH EFFLUENT.
 SEE P 23 AND 24, SPECIAL CONDITIONS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME DUQUESNE LIGHT COMPANY
ADDRESS BEAVER VALLEY ATOMIC POWER ST.
2841 NEW BEAVER AVENUE
PITTSBURGH PA 15233

FACILITY _____
LOCATION _____

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

PA0025615

PERMIT NUMBER

(17-19)

302 A

DISCHARGE NUMBER

F - FINAL LIMITS

302 A SEWAGE TREATMENT SYSTEM

Form Approved
OMB No. 2040-0004
Expires 2-29-84

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	84	08	01		84	08	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

ATTN: C. FEITKNECHT, GEN. SUPT

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (54-61)				NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-65)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	*****	*****	*****	*****	22	22		0	Once Month	
	PERMIT REQUIREMENT	*****	*****	*****	*****	30 30DA AV	45 7DA AV	MG/L		TWICE/COMP-8 MONTH	
PH	SAMPLE MEASUREMENT	*****	*****	*****	6.19	*****	6.88		0	31/ Month Grab	
00400 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU		TWICE/GRAB MONTH	
SOLIDS, TOTAL SUSPENDED 00530 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	*****	*****	*****	*****	21	24		0	31/ Month Grab	
	PERMIT REQUIREMENT	*****	*****	*****	*****	30 30DA AV	45 7DA AV	MG/L		TWICE/COMP-8 MONTH	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	0.006	0.007		*****	*****	*****	*****		Once/ Month Estim.	
	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****		TWICE/MEASRD MONTH	
COLIFORM, FECAL GENERAL 74055 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	*****	*****	*****	*****	0	0	#/	0	5/ Month Grab	
	PERMIT REQUIREMENT	*****	*****	*****	*****	200 30DA GEO	400 7DA GEO	100ML		TWICE/GRAB MONTH	
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

C. Feitknecht
General Manager
Fossil Generation Unit
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

412 393-4343

AREA
CODE

NUMBER

YEAR

MO

DAY

SAMPLES TAKEN AT LOC 0; SEWAGE TREATMENT SYSTEM PRIOR TO COMBINATION WITH OTHER EFFLUENT.
SEE P 23 AND 24, SPECIAL CONDITIONS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004
Expires 2-29-84

NAME **DUQUESNE LIGHT COMPANY**
ADDRESS **BEAVER VALLEY ATOMIC POWER ST.**
2841 NEW BEAVER AVENUE
PITTSBURGH PA 15233

PA0025615
PERMIT NUMBER

301 A
DISCHARGE NUMBER

F - FINAL LIMITS
301 A CLARIFIER BLOWDOWN

FACILITY
LOCATION

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	84	08	01		84	08	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
PH	SAMPLE MEASUREMENT	*****	*****	*****	7.38	*****	7.68		Twice	Grab
00400 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU	0	TWICE/GRAB MONTH
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	0.24	0.30		*****				Twice	Comp.
00530 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	2.8 DAILY AV	14.3 DAILY MX	LBS/DY	*****	***** DAILY AV	***** DAILY MX	MG/L	0	TWICE/COMP24 MONTH
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.003	0.012		*****	*****	*****	*****	31/ Month	Measrd
50050 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****	TWICE/MEASRD MONTH	
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

C. Feitknecht
General Manager
Fossil Generation Unit

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

412 393-4343
AREA CODE NUMBER

84 08 28
YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES TAKEN AT LOCATION 0; TREATED CLARIFIER BLOWDOWN & FILTER BKWSH, PRIOR TO EFFLUENT.
SEE P 23 AND 24, SPECIAL CONDITIONS.

DISCHARGE MONITORING REPORT (DMR)

F - FINAL LIMITS
003 A SANITARY WASTE

NAME **DUQUESNE LIGHT COMPANY**
ADDRESS **BEAVER VALLEY ATOMIC POWER ST.**
2841 NEW BEAVER AVENUE
PITTSBURGH PA 15233

PA0025615
PERMIT NUMBER

003 A
DISCHARGE NUMBER

FACILITY
LOCATION

MONITORING PERIOD						
FROM			TO			
YEAR	MO	DAY	YEAR	MO	DAY	
84	08	01	84	08	31	
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)	

ATTN: C. FEITKNECHT, GEN. SUPT

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (58-65)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
PH	SAMPLE MEASUREMENT	*****	*****	*****	8.66	*****	8.66	0	Once/ MONTH	Grab
00400 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.08	0.13		*****	*****	*****		Once Month	Calcd
50050 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****		ONCE/ MONTH	CALCTD
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319 (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	TELEPHONE		DATE		
C. Feitknecht General Manager Fossil Generation Unit		412 393-4343		84 07 31		
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO	DAY

SEE P 23 AND 24, SPECIAL CONDITIONS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **DUQUESNE LIGHT COMPANY**
 ADDRESS **BEAVER VALLEY ATOMIC POWER ST.**
2841 NEW BEAVER AVENUE
PITTSBURGH PA 15233

FACILITY
 LOCATION

ATTN: C. FEITKNECHT, GEN. SUPT

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

PA0025615

PERMIT NUMBER

201 A

DISCHARGE NUMBER

I - INITIAL LIMITS

201 A LOW VOLUME WASTE STREAM

Form Approved
 OMB No. 2040-0004
 Expires 2-29-84

No Discharge 201

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
PH	SAMPLE MEASUREMENT	*****	*****	*****		*****				
00400 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM		ONCE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	*****	*****					
00530 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*****	*****	30 DAILY AV	100 DAILY MX		ONCE/ MONTH	GRAB
OIL AND GREASE FREDN EXTR-GRAV METH	SAMPLE MEASUREMENT	*****	*****	*****	*****					
00556 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*****	*****	15 DAILY AV	20 DAILY MX		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT				*****	*****	*****	*****		
50050 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****	ONCE/ MONTH	ESTIMA
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

C. Feitknecht
 General Manager

Fossil Generation Unit

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

412 393-4343

AREA
 CODE

NUMBER

YEAR

MO

DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES TAKEN AT LOC 0, LOW VOLUME WASTE STREAMS PRIOR TO COMBINATION WITH OTHER EFFLUENT.
 SEE P 23 AND 24, SPECIAL CONDITIONS.

F - FINAL LIMITS
002 A SCREEN BACKWASH, ETCPERMITTEE NAME/ADDRESS (Include
Facility Name/Location if different)NAME **DUQUESNE LIGHT COMPANY**
ADDRESS **BEAVER VALLEY ATOMIC POWER ST.**
2841 NEW BEAVER AVENUE
PITTSBURGH PA 15233PA0025615
PERMIT NUMBER002 A
DISCHARGE NUMBER

(2-16)

(17-19)

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	84	08	01		84	08	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53) (54-61)			(4 Card Only) QUALITY OR CONCENTRATION (38-45) (46-53) (54-61)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
PH	SAMPLE MEASUREMENT	*****	*****	*****	7.53	*****	7.53		Once/ Month	Grab
00400 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	SU	ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.09	0.09		*****	*****	*****	*****	Once/ Month	Calctd
50050 1 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****	ONCE/ MONTH	CALCTD
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER C. Feitknecht General Manager Fossil Generation Unit TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319 (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE		
			AREA CODE	NUMBER	YEAR	MO	DAY
			412	393-4343	84	08	01

SEE P 29 AND EN, SPECIAL CONDITIONS (Attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **DUQUESNE LIGHT COMPANY**
 ADDRESS **BEAVER VALLEY ATOMIC POWER ST.**
2841 NEW BEAVER AVENUE
PITTSBURGH PA 15233

FACILITY
 LOCATION

ATTN: C. FEITKNECHT, GEN. SUPT

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16)

(17-19)

PA0025615

PERMIT NUMBER

103 A

DISCHARGE NUMBER

I - INITIAL LIMITS

103 A SOFTENER REGENERATES

Form Approved
 OMB No. 2040-0004
 Expires 2-29-84

MONITORING PERIOD

FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	84	08	01		84	08	31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29)	(30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS	MINIMUM	MAXIMUM			
SOLIDS, TOTAL SUSPENDED 00530 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1				0	Once Month	Grab
	PERMIT REQUIREMENT	*****	*****	*****	*****	30 DAILY AV	100 DAILY MX	MG/L				TWICE/GRAB MONTH	
OIL AND GREASE FREON EXTR-GRAY METH 00556 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	*****	*****	*****	*****	8	8				0	Once/ Month	Grab
	PERMIT REQUIREMENT	*****	*****	*****	*****	15 DAILY AV	20 DAILY MX	MG/L				TWICE/GRAB MONTH	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	0.020	0.020		*****	*****	*****	*****				Twice/ Month	Estima
	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****				TWICE/ESTIMA MONTH	
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

C. Feitknecht
 General Manager
 Fossil Generation Unit

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

TELEPHONE

DATE

SIGNATURE OF PRINCIPAL EXECUTIVE
 OFFICER OR AUTHORIZED AGENT

412 393-4343
 AREA CODE NUMBER

YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all applicable regulations)
 SAMPLES TAKEN AT LOC 0, SOFTENER REGENERATORS PRIOR TO COMBINATION WITH OTHER EFFLUENT.
 SEE P 23 AND 24, SPECIAL CONDITIONS.

NAME **DUQUESNE LIGHT COMPANY**
ADDRESS **BEAVER VALLEY ATOMIC POWER ST.**
2841 NEW BEAVER AVENUE
PITTSBURGH PA 15233

(2-16) **PA0025615**
PERMIT NUMBER
(17-19) **102 A**
DISCHARGE NUMBER

I - INITIAL LIMITS
102 A AUX BOILER BLOWDOWN

FACILITY
LOCATION

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
84	08	01	84	08	31
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

No Discharge 102

ATTN: **C. FEITKNECHT, GEN. SUPT**

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	SAMPLE MEASUREMENT PERMIT REQUIREMENT	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
COPPER, TOTAL (AS CU) 01042 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	*****	*****	*****	*****					
	PERMIT REQUIREMENT	*****	*****	*****	*****	***** DAILY AV	1 DAILY MX	MG/L	TWICE MONTH	GRAB
IRON, TOTAL (AS FE) 01045 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	*****	*****	*****	*****					
	PERMIT REQUIREMENT	*****	*****	*****	*****	***** DAILY AV	1 DAILY MX	MG/L	TWICE MONTH	GRAB
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER C. Feitknecht General Manager Fossil Generation Unit TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE 412 393-4343	DATE 84 08 29
---	---	--	----------------------------------	-------------------------

SAMPLES TAKEN AT LOC 01, BOILER BLOWDOWN PRIOR TO COMBINATION WITH OTHER EFFLUENT.
SEE P 23 AND 24, SPECIAL CONDITIONS.

PERMITTEE NAME/ADDRESS (Facility Name/Location if different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004
Expires 2-29-84

NAME **DUQUESNE LIGHT COMPANY**
ADDRESS **BEAVER VALLEY ATOMIC POWER ST.**
2841 NEW BEAVER AVENUE
PITTSBURGH PA 15233

(2-16)
PA0025615
PERMIT NUMBER

(17-19)
101 A
DISCHARGE NUMBER

F - FINAL LIMITS
101 A CHEMICAL WASTE SUMP

FACILITY
LOCATION

MONITORING PERIOD						
FROM	YEAR	MO	DAY	TO	YEAR	MO DAY
	84	08	01		84	08 31
	(20-21)	(22-23)	(24-25)		(26-27)	(28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
PH	SAMPLE MEASUREMENT	*****	*****	*****	7.30	*****	8.12		Four/	
00400 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	*****	6.0 MINIMUM	*****	9.0 MAXIMUM	SU	0	Month Grab TWICE/GRAB MONTH
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	5.12	8.54		*****				Twice/	
00530 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	3.8 DAILY AV	45 DAILY MX	LBS/DY	*****	***** DAILY AV	***** DAILY MX	MG/L	0	Month Grab TWICE/COMP24 MONTH
OIL AND GREASE FREON EXTR-GRAV METH	SAMPLE MEASUREMENT	1.46	2.76		*****				Twice/	
00556 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	1.9 DAILY AV	9.0 DAILY MX	LBS/DY	*****	***** DAILY AV	***** DAILY MX	MG/L	0	Month Grab TWICE/GRAB MONTH
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.022	0.075		*****	*****	*****	*****	4/	
50050 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	*****	*****	MGD	*****	*****	*****	*****	Month Calctd. TWICE/CALCTD MONTH	
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
C. Feitknecht
General Manager
Fossil Generation Unit
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 USC § 1001 AND 33 USC § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

412 393-4343
AREA CODE NUMBER

87 09 25
YEAR MO DAY

SAMPLES TAKEN AT LOCATION D; CHEM WASTE SUMP PRIOR TO COMBINATION WITH OTHER EFFLUENT.
SEE P 23 AND 24, SPECIAL CONDITIONS.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if different)

NAME **DUQUESNE LIGHT COMPANY**
ADDRESS **BEAVER VALLEY ATOMIC POWER ST.**
2841 NEW BEAVER AVENUE
PITTSBURGH PA 15233

FACILITY
LOCATION

ATTN: C. FEITKNECHT, GEN. SUPT

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

(2-16)

PA0025615

PERMIT NUMBER

(17-19)

001 A

DISCHARGE NUMBER

F - FINAL LIMITS

001 A COOLING TOWER BLOWDOWN

Form Approved
OMB No. 2040-0004
Expires 2-29-84

MONITORING PERIOD


FROM YEAR MO DAY TO YEAR MO DAY
84 08 01 84 08 31
(20-21) (22-23) (24-25) (26-27) (28-29) (30-31)

NOTE: Read instructions before completing this form.

PARAMETER (32-37)	X	(3 Card Only) QUANTITY OR LOADING (46-53)			(4 Card Only) QUALITY OR CONCENTRATION (38-45)			(5 Card Only) QUALITY OR CONCENTRATION (46-53)			NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
TEMPERATURE, WATER DEG. FAHRENHEIT 00011 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	*****	*****	94	DEG.F		Contin	Recorded
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****	*****			CONTINRCORR	UOUS
PH 00400 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	7.67	6.0	*****	*****	8.19	SU	0	4/31	Grab
	PERMIT REQUIREMENT	*****	*****	*****	MINIMUM	MAXIMUM	*****	*****	*****			CONTINRCORR	UOUS
OIL AND GREASE FREDN EXTR-GRAV METH 00556 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	9	*****	*****	9	MG/L	0	Once/Mch	Grab
	PERMIT REQUIREMENT	*****	*****	*****	*****	DAILY AV	*****	*****	DAILY MX			ONCE/	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 0 0 SEE COMMENTS BELOW	SAMPLE MEASUREMENT	22.08	36.97	MGD	*****	*****	*****	*****	*****	*****		Contin-	Recorded
	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	*****	*****	*****			CONTINRCORR	UOUS
CHLORINE, FREE AVAILABLE 50064 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.01	*****	*****	0.02	MG/L	0	Cont.	Record
	PERMIT REQUIREMENT	*****	*****	*****	*****	DAILY AV	*****	*****	DAILY MX			CONTINRCORR	UOUS
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												
	SAMPLE MEASUREMENT												
	PERMIT REQUIREMENT												

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
C. Feitknecht
General Manager
Fossil Generation Unit
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT


TELEPHONE
412 393-4343
AREA CODE NUMBER

DATE
84 09 28
YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SEE PAGE 2 OF PERMIT FOR INFORMATION REGARDING TEMPERATURE. LOCATION 0 IS THE COOLING TOWER BASIN.



One Oxford Centre
301 Grant Street
Pittsburgh, PA 15279

(412) 393-6000

DUQUESNE LIGHT COMPANY
Fossil Generation Unit
2841 New Beaver Avenue, Bldg. #3
Pittsburgh, PA 15233

September 28, 1984

Director of Nuclear Reactor Regulations
Attention: Mr. Robert W. Reid, Chief
Operating Reactor Branch, No. 4
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

NPDES Monthly Report

Subject: BVPS No. 1
Docket No. 50-334
License DPR-66

Dear Mr. Reid:

Enclosed is a copy of the subject report as submitted to the Pennsylvania Department of Environmental Resources.

Very truly yours,

C. Feitknecht
General Manager
Fossil Generation

CF:ag

Enclosure

IE25
11



One Oxford Centre
301 Grant Street
Pittsburgh, PA 15279

(412) 393-6000

DUQUESNE LIGHT COMPANY
Fossil Generation Unit
2841 New Beaver Avenue, Bldg. #3
Pittsburgh, PA 15233

September 28, 1984

U. S. Environmental Protection Agency
Region III, Pennsylvania Section (3WM52)
Water Permits Branch
Water Management Division
Sixth and Walnut Streets
Philadelphia, PA 19106

NPDES Monthly Report

Gentlemen:

This letter forwards copies of our NPDES Monthly Reports as submitted to the Pennsylvania Department of Environmental Resources, Bureau of Water Quality Management.

Very truly yours,

C. Feitknecht
General Manager
Fossil Generation

CL:ag

Enclosure



One Oxford Centre
301 Grant Street
Pittsburgh, PA 15279

(412) 393-6000

DUQUESNE LIGHT COMPANY
Fossil Generation Unit
2841 New Beaver Avenue, Bldg. #3
Pittsburgh, PA 15233

September 28, 1984

Department of Environmental Resources
Bureau of Water Quality Management
600 Highland Building
121 S. Highland Avenue
Pittsburgh, PA 15206-3988

NPDES Monthly Report

Gentlemen:

The subject reports for Duquesne Light Company for August, 1984 are submitted for your consideration. A list of the permit numbers follows:

PA 0001571	Elrama Power Station
PA 0001589	Shipp'sport Atomic Power Station
PA 0001619	Phillips Power Station
PA 0001627	Cheswick Power Station
PA 0025615	Beaver Valley Atomic Power Station
PA 0031933	Brunot Island Power Station

Very truly yours,

C. Feitknecht
General Manager
Fossil Generation

CF:ag

Enclosure