



ENTERGY

Entergy Operations, Inc.

1448 S.R. 333

Russellville, AR 72801

Tel 501 858-5000

October 16, 1995

ICAN109501

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
Monthly Operating Report

Gentlemen:

The Arkansas Nuclear One - Unit 1 Monthly Operating Report for September 1995 is attached. This report is submitted in accordance with ANO-1 Technical Specification 6.12.2.3.

Very truly yours,

Dwight C. Mims

Dwight C. Mims
Director, Licensing

DCM/eas

100083

9510190196 950930
PDR ADDCK 05000313
R PDR

IF 24
11

cc: Mr. Leonard J. Callan
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One
P.O. Box 310
London, AR 72847

Mr. George Kalman
NRR Project Manager Region IV/ANO-1 & 2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

OPERATING DATA REPORT

DOCKET NO: 50-313
 DATE: October 16, 1995
 COMPLETED BY: M. S. Whitt
 TELEPHONE: (501) 858-5560

OPERATING STATUS

1. Unit Name: Arkansas Nuclear One - Unit 1
2. Reporting Period: September 1-30
3. Licensed Thermal Power (MWt): 2,568
4. Nameplate Rating (Gross MWe): 903
5. Design Electrical Rating (Net MWe): 850
6. Maximum Dependable Capacity (Gross MWe): 883
7. Maximum Dependable Capacity (Net MWe): 836
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: _____
9. Power Level To Which Restricted. If Any (Net MWe): _____
10. Reasons For Restrictions. If Any: _____

	MONTH	YR-TO-DATE	CUMULATIVE
11. Hours in Reporting Period	720.0	6,551.0	182,178.0
12. Number of Hours Reactor was Critical	720.0	5,366.8	134,623.0
13. Reactor Reserve Shutdown Hours	0.0	0.0	5,044.0
14. Hours Generator On-Line	720.0	5,285.0	132,272.9
15. Unit Reserve Shutdown Hours	0.0	0.0	817.5
16. Gross Thermal Energy Generated (MWH)	1,845,410	12,665,411	306,819,300
17. Gross Electrical Energy Generated (MWH)	629,193	4,305,105	102,617,025
18. Net Electrical Energy Generated (MWH)	602,026	4,100,246	97,625,735
19. Unit Service Factor	100.0	80.7	72.6
20. Unit Availability Factor	100.0	80.7	73.1
21. Unit Capacity Factor (Using MDC Net)	100.0	74.9	64.1
22. Unit Capacity Factor (Using DER Net)	98.4	73.6	63.0
23. Unit Forced Outage Rate	0.0	2.6	10.3
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End of Report Period. Estimated Date of Startup: _____

26. Units in Test Status (Prior to Commercial Operation): _____

	Forecast	Achieved
INITIAL CRITICALITY	_____	08/06/74
INITIAL ELECTRICITY	_____	08/17/74
COMMERCIAL OPERATION	_____	12/19/74

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-313
UNIT: One
DATE: October 16, 1995
COMPLETED BY: M. S. Whitt
TELEPHONE: (501) 858-5560

MONTH September 1995

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	826
2	828
3	828
4	831
5	832
6	831
7	831
8	830
9	834
10	835
11	836
12	835
13	836
14	836
15	828
16	837
17	838
18	836
19	836
20	839
21	840
22	840
23	841
24	841
25	842
26	843
27	843
28	845
29	844
30	844
31	0

AVGS: 836

INSTRUCTION

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Complete to the nearest whole megawatt.

NRC MONTHLY OPERATING REPORT
OPERATING SUMMARY
SEPTEMBER 1995
UNIT ONE

The unit began the month of September operating at 100% power.

At 1900 hours on the fifteenth, a power reduction to 91% was commenced for turbine governor and throttle valve stroke testing. Following completion of the testing, the unit was returned to 100% power at 2345 hours the same day.

The unit operated the remainder of the month at 100% power.

**UNIT SHUTDOWNS AND POWER REDUCTIONS
REPORT FOR SEPTEMBER 1995**

DOCKET NO.	50-313
UNIT NAME	ANO Unit 1
DATE	October 16, 1995
COMPLETED BY	M. S. Whitt
TELEPHONE	501-858-5560

<u>NO.</u>	<u>DATE</u>	<u>TYPE¹</u>	<u>DURATION (HOURS)</u>	<u>REASON²</u>	<u>METHOD OF SHUTTING DOWN REACTOR³</u>	<u>LICENSEE EVENT REPORT #</u>	<u>SYSTEM CODE⁴</u>	<u>COMPONENT CODE⁵</u>	<u>CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE</u>
none									

¹
F: Forced
S: Scheduled

²
Reason:
A - Equipment Failure (Explain)
B - Maintenance of Test
C - Refueling
D - Regulatory Restriction
E - Operator Training & License Examination
F - Administration
G - Operational Error
H - Other (Explain)

³
Method:
1 - Manual
2 - Manual Scram.
3 - Automatic Scram.
4 - Continuation
5 - Load Reduction
9 - Other

⁴
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-0161)

⁵
Exhibit I - Same Source

REFUELING INFORMATION

1. Name of facility: Arkansas Nuclear One - Unit 1
2. Scheduled date for next refueling shutdown: September 20, 1996
3. Scheduled date for restart following refueling: November 4, 1996
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? If answer is yes, what, in general, will there be? If answer is no, has the reload fuel design and core configuration been reviewed by your Plant Safety Review Committee to determine whether any unreviewed safety questions are associated with the core reload (Ref. 10CFR Section 50.59)?

No, No
5. Scheduled date(s) for submitting proposed licensing action and supporting information:

NA
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.

None planned
7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool:

a) 177 b) 745
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:

present 968 increase size by 0
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity:

DATE: 1996 (Loss of full core off-load capability)