

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) LaSalle County Station Unit 1										DOCKET NUMBER (2) C 5 0 0 0 3 7 3										PAGE (3) 1 OF 02	
TITLE (4) Unsecured High Radiation Area Door																					
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)											
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES			DOCKET NUMBER(S)									
06	17	84	84	034	000	07	13	84				0 5 0 0 0									
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5. (Check one or more of the following) (11)																			
1		20.402(b)				20.406(c)				50.73(a)(2)(iv)				73.71(b)							
POWER LEVEL (10)		20.406(a)(1)(i)				50.36(c)(1)				50.73(a)(2)(v)				73.71(c)							
1 0 0		20.406(a)(1)(ii)				50.36(c)(2)				50.73(a)(2)(vii)				OTHER (Specify in Abstract below and in Text, NRC Form 366A)							
		20.406(a)(1)(iii)				50.73(a)(2)(i)				50.73(a)(2)(viii)(A)											
		20.406(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(B)											
		20.406(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(ix)											
LICENSEE CONTACT FOR THIS LER (12)																					
NAME Lary R. Aldrich, extension 238										TELEPHONE NUMBER AREA CODE 8 1 5 3 5 1 7 1 - 1 6 7 6 1 1											
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																					
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC											
A	ZIZ	Z191919	Z191919	N																	
SUPPLEMENTAL REPORT EXPECTED (14)										EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR							
YES (If yes, complete EXPECTED SUBMISSION DATE)										X NO											

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

At 0515 on June 17, 1984, a high radiation area door, which leads to the URC tank room on the 687' elevation of the Turbine Building, was found open with no positive access control. Individuals entered the room during the hours of 1525 on June 16, 1984 to 0455 on June 17, 1984. Upon leaving the room, the door was not closed and secured. Upon discovery of the lack of security control of the high radiation area, a Radiation Chemistry Technician closed and secured the door.

8407240376 840713
PDR ADOCK 05000373
S PDRIE22
1/1

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMS NO. 3150-0104

EXPIRES: 8/31/85

FACILITY NAME (1) LaSalle County Station Unit 1	DOCKET NUMBER (2) 0 5 0 0 0 3 7 3	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
		8 4	0 3 4	0 0	0 2	OF	0 2

TEXT (If more space is required, use additional NRC Form 368A) (17)

I. EVENT DESCRIPTION

At 0515 on June 17, 1984, a high radiation area door, which leads to the URC tank room on the 687' elevation of the Turbine Building, was found open with no positive access control. Contrary to Technical Specification 6.1.1., the room was found to be unsecured and unattended.

II. CAUSE

Individuals entered the room during the hours of 1525 on June 16, 1984 to 0455 on June 17, 1984. Upon leaving the room, the door was not closed and secured.

III. PROBABLE CONSEQUENCES OF THE OCCURRENCE

Review of the dosimetry data for the period in question indicates that no unauthorized radiation exposure greater than 50 mrem occurred.

IV. CORRECTIVE ACTION

Upon discovery of the lack of security control of the high radiation area, a Radiation Chemistry Technician (RCT) closed and secured the door. Emphasis is continuing to remind all workers of the requirements and responsibilities of all personnel when dealing with high radiation areas.

V. PREVIOUS OCCURRENCES

Previous unsecured high radiation door LER's were 373/84-25-00, 373/84-036-00, and 374/84-022-00.

IV. NAME AND TELEPHONE NUMBER OF PREPARER

L. R. Aldrich, 815/357-6761, extension 238.



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

July 13, 1984

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Reportable Occurrence Report #84-034-00, Docket #050-373 is being submitted to your office in accordance with 10 CFR 50.73.

C E Dargatz

for G. J. Diederich
Superintendent
LaSalle County Station

GJD/MLD/kg

Enclosure

xc: NRC, Regional Director
INPO-Records Center
File/NRC

IE22
11