

482

RECEIVED BY THE DIRECTOR

LAW OFFICES OF
BISHOP, LIBERMAN, COOK, PURCELL & REYNOLDS

1200 SEVENTEENTH STREET, N. W.
WASHINGTON, D. C. 20036
(202) 857-9900
TELEX 440574 INTLAW UI

DOCKETED
USNRC

IN NEW YORK
BISHOP, LIBERMAN & COOK
26 BROADWAY
NEW YORK, NEW YORK 10004
(212) 248-6200
TELEX 222767

'84 JUL 24 A10:34

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH

July 20, 1984

Peter B. Bloch, Esq.
Chairman, Atomic Safety and
Licensing Board
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Dr. Walter H. Jordan
881 West Outer Drive
Oak Ridge, Tennessee 37830


Dr. Kenneth A. McCollom
Dean, Division of Engineering,
Architecture and Technology
Oklahoma State University
Stillwater, Oklahoma 74074

Re: Texas Utilities Electric Company, et al.
Comanche Peak Steam Electric Station,
Units 1 and 2 (Docket Nos. 50-445 and 50-446) OL

Gentlemen:

In accordance with our obligation to apprise the Board of matters which may bear on issues before it, this will advise that Applicants have concluded that certain fire dampers at Comanche Peak are installed at variance with the Underwriters Laboratories ("UL") test configuration. This variance was detected by Applicants during normal testing of the dampers. In view of the variance, the reliability of operation of these dampers, as installed, is not supported by UL tests. Applicants presently envisage that rework or minor modifications are necessary for approximately 33 dampers. These facts have been reported by Applicants to NRC Region IV pursuant to 10 C.F.R. Part 50.55(e), and to the NRC Staff's Comanche Peak Technical Review Team (T.A. Ippolito, Project Director).

Sincerely,



Nicholas S. Reynolds
Counsel to Applicants

cc: Service List

8407250271 840720
PDR ADOCK 05000445
G PDR

DS03