



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

June 27, 1984 84 JUL 9 A 9:16

NUCLEAR LICENSING & SAFETY DEPARTMENT

U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30323

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File: 0260/L-835.0  
Special Report 84-021/1 - Update  
Report - Fire Door 1A320 Blocked  
Open to Support Planned  
Maintenance Activities  
AECM-84/0324

This is an update to a previous report submitted on May 15, 1984. The condition for which the report was submitted began on April 8, 1984, when fire door 1A320 to the Main Steam Tunnel Room was blocked open to support planned maintenance activities. Fire watches were established in accordance with Technical Specification 3.7.7. The maintenance outage is continuing and work is still being performed in the Main Steam Tunnel. Fire watches will be continued until the fire door is restored. This is submitted as a Special Report pursuant to Technical Specification 6.9.2. This is a final report.

Yours truly,

L. F. Dale  
Director of Nuclear Licensing & Safety

EBS/SHH:rg

cc: Mr. J. B. Richard  
Mr. R. B. McGehee  
Mr. N. S. Reynolds  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555