

Director, Office of Resource Management
 March Monthly Operating Report
 Page 3
 April 10, 1984
 Revised -- July 11, 1984

ATTACHMENT II
 OPERATING DATA REPORT

DOCKET NO. 50/395
 UNIT V. C. SUMMER I
 DATE 04/10/84
 COMPLETED BY G. A. Loignon
 TELEPHONE (803) 345-5209

OPERATING STATUS

1. Reporting Period: MARCH 1984 Gross Hours in Reporting Period: 744
2. Currently Authorized Power Level (MWt): 2775
 Max. Depend. Capacity (MWe-Net): 885
 Design Electrical Rating (MWe-Net): 900
3. Power Level to which restricted (If Any) (MWe-Net): N/A
4. Reasons for Restrictions (If Any): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. Number of Hours Reactor Was Critical	533.5	1,910.3	1,910.3
6. Reactor Reserve Shutdown Hours	0	0	0
7. Hours Generator on Line	531.5	1,875.7	1,875.7
8. Unit Reserve Shutdown Hours	0	0	0
9. Gross Thermal Energy Generated (MWH)	1,459,743	5,122,987	5,122,987
10. Gross Electrical Energy Generated (MWH)	490,650	1,713,230	1,713,230
11. Net Electrical Energy Generated (MWH)	468,655	1,640,182	1,640,182
12. Reactor Service Factor	71.7	87.5	87.5
13. Reactor Availability Factor	71.7	87.5	87.5
14. Unit Service Factor	71.4	85.9	85.9
15. Unit Availability Factor	71.4	85.9	85.9
16. Unit Capacity Factor (Using MDC)	71.2	84.9	84.9
17. Unit Capacity Factor (Using Design MWe)	70.0	83.4	83.4
18. Unit Forced Outage Rate	0.0	4.9	4.9

19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
Scheduled refueling - September 1, 1984

20. If Shut Down at End of Report Period, Estimated Date of Startup: April 18, 1984

21. Units in Test Status (Prior to Commerical Operation):

	FORECAST	ACHIEVED
Initial Criticality	N/A	10-22-82
Initial Electricity	N/A	11-16-82
Commercial Operation	N/A	01-01-84