

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Monticello										DOCKET NUMBER (2) 0 5 0 0 0 2 6 3				PAGE (3) 1 OF 0 2		
TITLE (4) SBGTS Initiation from Reactor Building Ventilation WRGM Trip.																
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)						
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)			
0 9	1 0	8 4	8 4	0 2 6	0 0	1 0	1 0	8 4					0 5 0 0 0			
OPERATING MODE (9) N			THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)													
POWER LEVEL (10) 0 1 0 1 0			20.402(b)				20.408(e)				X 50.73(a)(2)(iv)				73.71(b)	
			20.408(a)(1)(i)				50.36(a)(1)				50.73(a)(2)(v)				73.71(e)	
			20.408(a)(1)(ii)				50.36(a)(2)				50.73(a)(2)(vi)				OTHER (Specify in Abstract below and in Text, NRC Form 308A)	
			20.408(a)(1)(iii)				50.73(a)(2)(i)				50.73(a)(2)(vii)(A)					
			20.408(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(B)					
			20.408(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(ix)					
LICENSEE CONTACT FOR THIS LER (12)																
NAME Edward Lieftring, Radiation Protection Specialist										TELEPHONE NUMBER 6 1 2 2 9 5 - 5 1 5 1						
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS						
SUPPLEMENTAL REPORT EXPECTED (14)												EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR
YES (If yes, complete EXPECTED SUBMISSION DATE)												X NO		1 1 0	1 0	8 4

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On September 10, 1984, a Reactor Building Isolation and initiation of Standby Gas Treatment occurred when two Inop. signals were received from the Reactor Building Ventilation Wide Range Gas Monitors. The second Inop. signal was caused by the closure of the wrong sample valve. The sample valve was opened, clearing the Inop. signal. To prevent recurrence, the sample procedure is being revised and additional training will be given.

IE 22
1/1

8410190052 841010
PDR ADOCK 05000263
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO. 3150-0104
EXPIRES: 9/31/86

FACILITY NAME (1) Monticello	DOCKET NUMBER (2) 0 5 0 0 0 2 6 3 8 4 - 0 2 6 - 0 0 0 2	LER NUMBER (5)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			

TEXT (If more space is required, use additional NRC Form 308A's) (17)

During cold shutdown on September 10, 1984 Channel A Reactor Building Ventilation Wide Range Gas Monitor (RI) was being tested. As part of this test, an Inop. signal was in on Channel A. During this test an Inop. signal was received from Channel B Reactor Building Ventilation Wide Range Gas Monitors (RI). With both Reactor Building Ventilation Wide Range Gas Monitors being inoperable, Reactor Building Isolation (VA) and initiation of Standby Gas Treatment System (BH) occurred. The Inop. signal on Channel B was caused by the closure of the wrong sample valve, during a weekly grab sample filter changeout. The valve was opened, clearing the Inop. signal.

Contrary to approved procedure, the wrong sample valve was mistakenly closed by a utility Chemistry Technician.

The event had no effect on public health or safety.

To prevent recurrence of this event a caution statement is being placed on the Wide Range Gas Monitor sample filter changeout procedure. Additional training will be given to personnel involved with filter changeout.

Previous similar occurrence report in LER 84-020.



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

October 10, 1984

U S Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Monitcello NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

SBGTS Initiation From Reactor Building
Ventilation WRCM Trip

The License Event Report for this occurrence is attached.

This event was reported via Emergency Notification System per 10 CFR Part 72
on September 10, 1984.

M. M. Vick

for David Musolf
Manager - Nuclear Support Services

DMM/MMV/le

c: Regional Administrator-III, NRC
NRR Project Manager, NRC
Resident Inspector, NRC
MPCA
Attn: J W Ferman

Attachment

*IE22
11*