



CHARLES CENTER • P. O. BOX 1475 • BALTIMORE, MARYLAND 21203

October 8, 1984

ARTHUR E. LUNDVALL, JR.
VICE PRESIDENT
SUPPLY

Director of Nuclear Reactor Regulation
Attention: Mr. J. R. Miller, Chief
Operating Reactors Branch #3
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Calvert Cliffs Nuclear Power Plant
Units Nos. 1 & 2; Dockets Nos. 50-317 and 50-318
Environmental Qualification of Electrical Equipment

Gentlemen:

Please be informed that we have completed formal qualification of the hydrogen purge control valve motor operator (MOV-6902) by means of replacement of certain non-metallic internal components with components manufactured from qualified materials. This resolves the environmental qualification deficiency which was discussed with your staff by telephone on September 18, 1984.

Very truly yours,

AEL/BSM/vf

cc: D. A. Brune, Esq.
G. F. Trowbridge, Esq.
Mr. D. H. Jaffe, NRC
Mr. T. Foley, NRC

A048
1/0

8410190064 841008
PDR ADOCK 05000317
P PDR