

3.23 REACTOR BUILDING PURGE VALVES

APPLICABILITY

This specification applies to the reactor building purge supply and exhaust isolation valves.

OBJECTIVE

To specify that reactor building isolation purge valves be closed whenever containment integrity is required by TS 3.6.1.

SPECIFICATION

- 3.23.1 The reactor building purge supply and exhaust isolation valves shall be closed and handswitch keys removed whenever containment integrity is required by TS 3.6.1.

BASES

The reactor building supply and exhaust isolation valves are required to be closed during normal plant operation in order to ensure reactor building integrity. Purging is allowed only when containment integrity is not required by TS3.6.1.

CONTAINMENT SYSTEMS

CONTAINMENT VENTILATION SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.1.6 The containment purge supply and exhaust isolation valves shall be closed and handswitch keys removed.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With one containment purge supply and/or exhaust isolation valve open, close the open valve(s) with 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.6 The containment purge supply and exhaust isolation valves shall be determined closed at least once per 31 days.